

NORMAL NORMAL SWITCHBOARD 'SWBDRB' CIRCUIT SCHEDULE

TITLE: SWBDRB		APP: SWB: 200A		MAIN USES:		INSULATING CAPACITY: 42 KV		
WORKING SURFACE		PHASE: 3		MAIN BREAKER: 200A		DESCRIPTION: 42 KV		
NO.	BRKNGS	DESCRIPTION	PHASE A	PHASE B	PHASE C	BRKNGS	CIR	
NO.	AMPS	TYPE				AMPS	TYPE	
1	150	3	4S-15			400	3	
3	800	3	4S-80			800	3	
5	800	3	4S-80P			1200	3	
7	3	3				3	8	
9	3	3				3	10	
11	3	3	SWMC			3	12	
13	3	3	SWMC			3	14	
KVA TOTALS			0.0	0.0	0.0	0.0	0.0	
TOTAL KVA							0.0	
TOTAL AMPS							0.0	

CRITICAL SWITCHBOARD 'SWBDRB' CIRCUIT SCHEDULE

TITLE: SWBDRB		APP: SWB: 100A		MAIN USES:		INSULATING CAPACITY: 50 KV		
WORKING SURFACE		PHASE: 3		MAIN BREAKER: 100A		DESCRIPTION: 50 KV		
NO.	BRKNGS	DESCRIPTION	PHASE A	PHASE B	PHASE C	BRKNGS	CIR	
NO.	AMPS	TYPE				AMPS	TYPE	
1	150	3	4S-15			400	3	
3	800	3	4S-80			800	3	
5	800	3	4S-80P			3	6	
7	3	3	SWMC			3	8	
9	3	3	SWMC			3	10	
11	3	3	SWMC			3	12	
13	3	3	SWMC			3	14	
KVA TOTALS			0.0	0.0	0.0	0.0	0.0	
TOTAL KVA							0.0	
TOTAL AMPS							0.0	

CRITICAL DISTRIBUTION PANEL 'DPDRBQ2B1' CIRCUIT SCHEDULE

TITLE: DPDRBQ2B1		APP: SWB: 30A		MAIN USES:		INSULATING CAPACITY: 50 KV		
WORKING SURFACE		PHASE: 3		MAIN BREAKER: 30A		DESCRIPTION: 50 KV		
NO.	BRKNGS	DESCRIPTION	PHASE A	PHASE B	PHASE C	BRKNGS	CIR	
NO.	AMPS	TYPE				AMPS	TYPE	
1	600	3	MC-6			3	2	
3	3	3				3	4	
5	3	3				3	6	
7	3	3	SWMC			3	8	
9	3	3	SWMC			3	10	
11	3	3	SWMC			3	12	
13	3	3	SWMC			3	14	
KVA TOTALS			0.0	0.0	0.0	0.0	0.0	
TOTAL KVA							0.0	
TOTAL AMPS							0.0	

NORMAL DISTRIBUTION PANEL 'DPDRNAB1' CIRCUIT SCHEDULE

TITLE: DPDRNAB1		APP: SWB: 40A		MAIN USES:		INSULATING CAPACITY: 42 KV		
WORKING SURFACE		PHASE: 3		MAIN BREAKER: 40A		DESCRIPTION: 42 KV		
NO.	BRKNGS	DESCRIPTION	PHASE A	PHASE B	PHASE C	BRKNGS	CIR	
NO.	AMPS	TYPE				AMPS	TYPE	
1	3	3	PANEL TOP-R			3	2	
3	3	3				3	4	
5	3	3				3	6	
7	3	3				3	8	
9	3	3				3	10	
11	3	3	SWMC			3	12	
13	3	3	SWMC			3	14	
KVA TOTALS			0.0	0.0	0.0	0.0	0.0	
TOTAL KVA							0.0	
TOTAL AMPS							0.0	

EQUIPMENT DISTRIBUTION PANEL 'DPDRB1' CIRCUIT SCHEDULE

TITLE: DPDRB1		APP: SWB: 30A		MAIN USES:		INSULATING CAPACITY: 63 KV		
WORKING SURFACE		PHASE: 3		MAIN BREAKER: 30A		DESCRIPTION: 63 KV		
NO.	BRKNGS	DESCRIPTION	PHASE A	PHASE B	PHASE C	BRKNGS	CIR	
NO.	AMPS	TYPE				AMPS	TYPE	
1	3	3				3	2	
3	3	3				3	4	
5	3	3				3	6	
7	3	3	SWMC			3	8	
9	3	3	SWMC			3	10	
11	3	3	SWMC			3	12	
13	3	3	SWMC			3	14	
KVA TOTALS			0.0	0.0	0.0	0.0	0.0	
TOTAL KVA							0.0	
TOTAL AMPS							0.0	

NORMAL DISTRIBUTION PANEL 'DPDRNAB1' CIRCUIT SCHEDULE

TITLE: DPDRNAB1		APP: SWB: 40A		MAIN USES:		INSULATING CAPACITY: 42 KV		
WORKING SURFACE		PHASE: 3		MAIN BREAKER: 40A		DESCRIPTION: 42 KV		
NO.	BRKNGS	DESCRIPTION	PHASE A	PHASE B	PHASE C	BRKNGS	CIR	
NO.	AMPS	TYPE				AMPS	TYPE	
1	3	3	PANEL TOP-R			3	2	
3	3	3				3	4	
5	3	3				3	6	
7	3	3				3	8	
9	3	3				3	10	
11	3	3	SWMC			3	12	
13	3	3	SWMC			3	14	
KVA TOTALS			0.0	0.0	0.0	0.0	0.0	
TOTAL KVA							0.0	
TOTAL AMPS							0.0	


EQUIPMENT DISTRIBUTION PANEL 'DPDRB1' CIRCUIT SCHEDULE

TITLE: DPDRB1		APP: SWB: 30A		MAIN USES:		INSULATING CAPACITY: 63 KV		
WORKING SURFACE		PHASE: 3		MAIN BREAKER: 30A		DESCRIPTION: 63 KV		
NO.	BRKNGS	DESCRIPTION	PHASE A	PHASE B	PHASE C	BRKNGS	CIR	
NO.	AMPS	TYPE				AMPS	TYPE	
1	3	3				3	2	
3	3	3				3	4	
5	3	3				3	6	
7	3	3	SWMC			3	8	
9	3	3	SWMC			3	10	
11	3	3	SWMC			3	12	
13	3	3	SWMC			3	14	
KVA TOTALS			0.0	0.0	0.0	0.0	0.0	
TOTAL KVA							0.0	
TOTAL AMPS							0.0	

CRITICAL DISTRIBUTION PANEL 'DPDRBQ2B1' CIRCUIT SCHEDULE

TITLE: DPDRBQ2B1		APP: SWB: 30A		MAIN USES:		INSULATING CAPACITY: 50 KV		
WORKING SURFACE		PHASE: 3		MAIN BREAKER: 30A		DESCRIPTION: 50 KV		
NO.	BRKNGS	DESCRIPTION	PHASE A	PHASE B	PHASE C	BRKNGS	CIR	
NO.	AMPS	TYPE				AMPS	TYPE	
1	600	3	MC-6			3	2	
3	3	3				3	4	
5	3	3				3	6	
7	3	3	SWMC			3	8	
9	3	3	SWMC			3	10	
11	3	3	SWMC			3	12	
13	3	3	SWMC			3	14	
KVA TOTALS			0.0	0.0	0.0	0.0	0.0	
TOTAL KVA							0.0	
TOTAL AMPS							0.0	

ISSUE DATE: 09/24/14
 FOR PERMIT ONLY - NOT FOR CONSTRUCTION
 SCALE: LOG



TRO
 ARCHITECTURE
 PLANNING
 ENGINEERING
 INTERIORS
 The TRO Group
 80 Water Street
 Portland, ME 04101
 Phone: 603.761.1100
 Fax: 603.761.1101
 www.trogroup.com

Maine Medical Center
 Charles Street Project
 Portland, Maine
 MMC Project No. 21841

ELECTRICAL SCHEDULES SHEET 3 OF 3

Commission No. 4522 | Exam Number
 Scale: Sheet Number
 Drawn By: E.S.
 Checked By: E.S.
 Revision: 09/14/14
 Project: 1418700.00
 Date: 09/24/14

E703