


- General Notes:
- 1 PROVIDE A MINIMUM OF 3'-0" SERVICE CLEARANCE IN FRONT OF PIP STATION.
 - 2 SEE STEAM SYSTEM COMPONENTS, DETAILS AND SCHEDULES FOR PIP PIPING AND COMPONENTS.
 - 3 FOR CONNECTION OF VENT PIPING, SEE STEAM SYSTEM SCHEDULES.
 - 4 STEAM SUPPLY AND RETURN PIPING LOCATED HIGH, ABOVE AND COORDINATED WITH STRUCTURAL ENGINEER FOR A MINIMUM CLEARANCE OF 8'-0" ABOVE THE PIPING. BRASS WRENCHER PIPES CROSS THE PLANE OF ONE OF THE REQUIREMENTS. VENT ALL HIGH PIPING POINTS AND RETURN PIPING TO THE MECHANICAL ROOM. RETURN PIPING BE 8'-0" A.F.F. EXCEPT CONDENSATE RETURN PIPING.
 - 5 ALL UPH STEAM CONDENSATE THIS FLOOR, DROPS DOWN THEN SHALLOU TO MAKE THE D.P. SIDE OF THE CONDENSATE TRAP.
 - 6 RA W/LETTER FOR DAC-1.
 - 7 SEE REQUIREMENTS SET WITH WATER, SEWAGE, AND STEAM SCHEDULES FOR CONNECTION DETAILS. PROVIDE CONNECTIONS FOR R.O. CONTROL OF VALVES. SEE PIPING SCHEDULES FOR R.O. CONTROL OF VALVES. SEE PIPING SCHEDULES FOR R.O. CONTROL OF VALVES.
 - 8 VENT PIPING FROM ROOM DOWN TO MECHANICAL ROOM. SEE CLEAN STEAM SCHEDULES FOR SCHEDULES OF PIPING.

SEE ONE FOR PERMIT ONLY
NOT FOR CONSTRUCTION



PRO
A. ELECTRICIAN
S. PLUMBING
I. TYPING
The Maine Center
Mechanical Engineering
1000 Main Street
Portland, ME 04102

Maine Medical Center
Charles Street Project
Portland, Maine
MMC Project No. 21841

**HVAC FIFTH FLOOR
MECHANICAL ROOM PLAN
PIPPING**

Commission No.	4322	Draw Number	
Scale	1/2" = 1'-0"	Sheet Number	
Drawn By	JK	Checked By	
Revised By		Revised By	
Project No.	4322	Project Name	
Sheet No.		Sheet Title	
			H401