


LIGHT FIXTURE SCHEDULE					
TYPE	DESCRIPTION	MFR.	LAMPS	MOUNTING	NOTES
A	2x4 SPECIFICATION GRADE RECESSED TROFFER W/PATTERN A12 ACRYLIC LENS. 120V/277V	COLUMBIA 4PS SERIES	3-F32T8 3500K	CEILING RECESSED	UTILIZE ALL EXISTING TYPE A FIXTURES AND PROVIDE 6 ADDITIONAL FIXTURES.
B	2x4 PARABOLIC TROFFER W/SEMI-SPECULAR REFLECTOR. 18 CELL, 3" DEEP LOUVER. 120V/277V	EXISTING TO BE RELOCATED	3-F32T8 3500K	CEILING RECESSED	
C	2x2 SPECIFICATION GRADE RECESSED TROFFER W/PATTERN A12 ACRYLIC LENS. 120V/277V	EXISTING TO BE RELOCATED	2-F31UT8 3500K	CEILING RECESSED	


**NOTES:**  
1. SEE E-001 FOR THE LEGEND AND GENERAL NOTES.

- KEYED NOTES:**
- EXISTING PARABOLIC FIXTURE TO BE REMOVED AND REPLACED WITH NEW LENSED TROFFER. RECONNECT EXISTING BRANCH CIRCUIT AND SWITCH TO NEW LIGHT FIXTURE. INSTALL NEW OCCUPANCY SENSOR WIRED TO LIGHT SWITCH. EXISTING LINE SIDE WIRING TO LIGHT SWITCH.
  - RELOCATE EXISTING LIGHT SWITCH FROM CURRENT LOCATION SHOWN ON ED101 AND EXTEND EXISTING WIRING AS REQUIRED TO NEW SWITCH LOCATION. PROVIDE NEW OCCUPANCY SENSOR FOR CONTROL OF LIGHT.
  - PROVIDE NEW SWITCH AND OCCUPANCY SENSOR TO CONTROL EXISTING LIGHTS. MODIFY EXISTING WIRING AS REQUIRED.
  - RELOCATE EXISTING LIGHTS AND SWITCH FROM CURRENT LOCATION SHOWN ON ED101 AND EXTEND EXISTING WIRING AS REQUIRED TO REFEED LIGHTS. PROVIDE NEW OCCUPANCY SENSOR FOR CONTROL OF LIGHT.
  - PROVIDE NEW LIGHTS AND OCCUPANCY SENSOR SWITCHES AND UTILIZE EXISTING BRANCH CIRCUIT THAT FED LIGHT SHOWN TO BE REMOVED ON ED101 TO FEED NEW LIGHTS.
  - RELOCATE CORRIDOR LIGHT SWITCHES FROM CURRENT LOCATION SHOWN ON ED101 AND EXTEND EXISTING WIRING AS REQUIRED TO ACCOMMODATE NEW SWITCH LOCATION.



REV	DESCRIPTION	DATE
0	ISSUED FOR CONSTRUCTION	4-25-17


**ISSUED FOR CONSTRUCTION**  
4-25-17  
CURRENT ISSUE STATUS:



PROJECT NORTH:  
SMRT Architects and Engineers  
144 Fore Street  
Portland, Maine 04104  
1.877.700.7678  
www.smrtainc.com  
ARCHITECTURE | ENGINEERING | PLANNING | INTERIORS | ENERGY

**MAINE MEDICAL PARTNERS  
SURGICAL CARE RENOVATIONS**

PORTLAND, MAINE  
**LEVEL 4  
LIGHTING PLAN**



SCALE: AS NOTED  
PROJECT MANAGER: DJV PROJECT NO: 17027  
A/E OF RECORD: DJT  
JOB CAPTAIN: CAH  
DRAWN BY: CDS  
SMRT FILE: EL101-17027 SHEET No. ©COPYRIGHT 2015 SMRT INC.

**LEVEL 4 - LIGHTING PLAN** (A1)  
1/8" = 1' - 0"