City of I tland, Maine - Building or Use Permit Applicat 389 Congress Street, 04101, Tel: (207) 874-8703, 1 Owner: Location of Construction: Phone: Permit Non d63-903 Congress St. Port Land, Se. 04101 Maine Medical Center (207)#772-6009# PORC Lessee/Buyer's Name: Owner Address: Phone: BusinessName: Maine Surgical Conter Permit Issued Contractor Name: Address: Phone: Granger Horthern, Inc. 3 1999 COST OF WORK: PERMIT FEE: Past Use: Proposed Use: \$1,272,186.00 Shell Space \$5,461.00 precut Physician Offices FIRE DEPT. Approved INSPECTION: Use Group: 3 Type 2 C □ Denied CBL: 053-1-001 BOCK 16 Zone: Signature: Signature: Proposed Project Description: Zoning Approval: PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Tenant Fit-Up Action: Approved Special Zone or Reviews: STE. #'s 400, 410, 200, 210, 8 300. Approved with Conditions: ☐ Shoreland Denied □Wetland ☐ Flood Zone ☐ Subdivision Signature: Date: ☐ Site Plan maj ☐minor ☐mm ☐ Permit Taken By: Date Applied For: S.F. May 5ch, 1999 Zoning Appeal □ Variance This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules. ☐ Miscellaneous 2. Building permits do not include plumbing, septic or electrical work. ☐ Conditional Use Building permits are void if work is not started within six (6) months of the date of issuance. False informa-□ Interpretation □Approved tion may invalidate a building permit and stop all work... □Denied Call Ros Mischwell For Pickup- 87246039 772-6009 Historic Preservation □ Not in District or Landmark ☐ Does Not Require Review ☐ Requires Review Action: CERTIFICATION □Appoved ☐ Approved with Conditions I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been ☐ Denied authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all Date: areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE

SIGNATURE OF APPLICANT

PHONE:

PHONE:

May 6th, 1999

CEO DISTRICT

ADDRESS:

THIS IS NOT A PERMIT/CONSTRUCTION CANNOT COMMENCE UNTIL THE PERMIT IS ISSUED

Building or Use Permit Pre-Application Attached Single Family Dwellings/Two-Family Dwelling Multi-Family or Commercial Structures and Additions Thereto

In the interest of processing your application in the quickest possible manner, please complete the Information below for a Building or Use Permit.

NOTE**If you or the property owner owes real estate or personal property taxes or user charges on ANY PROPERTY within the City, payment arrangements must be made before permits of any kind are accepted.

Location/Addressof Construction (include Portion of Building)	883-903 CONGRESS
Total Square Footage of Proposed Structure	Square Footage of Lot
Tax Assessor's Chart, Block & Lot Number Chart# 33 Block# Lot# 201	Owner MAINE MEDICAL CTIL TTELEPHONE# MMBC
Owner's Address: 22 BRAMHALL ST. PORTLAND, ME	Lessee/Buyer's Name (If Applicable) Cost Of Warky 2, 186 Fee 18
Proposed Project Description:(Please be as specific as possible)	1
TENANT FIT. UP	STE# 400, 410,
Contractor's Name, Address & Telephone GRANG	SER NORTHERN INC. PONDERWELL
Current Use: SHELL SPACE	Proposed Use PHYSICIAN OFFICES
 All construction must be conducted in complete All plumbing must be conducted. All Electrical Installation must complete All C(Heating, Ventiliation and Air Conduction). 	ed for Internal & External Plumbing, HVAC and Electrical installation liance with the 1996 B.O.C.A. Building Code as amended by Section 6-Art II. ucted in compliance with the State of Maine Plumbing Code. with the 1996 National Electrical Code as amended by Section 6-Art III. iditioning) installation must comply with the 1993 BOCA Mechanical Code.
You must Include the following with you application	on: If Your Deed or Purchase and Sale Agreement of your Construction Contract, if available 3) A Plot Plan/Site Plan
	of your Construction Contract, if available
	5) A Flot Hall/Site Hall
Minor or Major site plan review will be required for	11-31
checklist outlines the minimum standards for a site	e plan. 4) Building Plans
	4) Dunuing I laus

Unless exempted by State Law, construction documents must be designed by a registered design professional. A complete set of construction drawings showing all of the following elements of construction:

Cross Sections w/Framing details (including porches, decks w/ railings, and accessory structures)

Floor Plans & Elevations

Signat

- Window and door schedules
- Foundation plans with required drainage and dampproofing
- Electrical and plumbing layout. Mechanical drawings for any specialized equipment such as furnaces, chimneys, gas equipment, HVAC equipment (air handling) or other types of work that may require special review must be included.

Certification

I hereby certify that I am the Owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his/her authorized agent. I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in this application is issued, I certify that the Code Official's authorized representative shall have the authority to enter all areas covered by this permit at any reasonable hour to enforce th

ne provisions of the codes applicable to this permit.		
ure of applicant: Row Bullinger	Date: 4/30/99	
Building Permit Fee: \$25.00 for the 1st \$1000.cost plus \$5.00 per	er \$1,000.00 construction cost thereafter	
Additional Site review and related fees are attached	d on a separate addendum	

BUILDING PERMIT REPORT	
ATE: 5/11/99 ADDRESS: 883-903 Conjuly St CBL: US3-I-00)	
REASON FOR PERMIT: Tenent Fity	
BUILDING OWNER: M PO C	
PERMIT APPLICANT: Ron Blackwell 1Contractor Granger Northern.	Inc.
USE GROUP_B BOCA 1996 CONSTRUCTION TYPE_Z6	
CONDITION(S) OF APPROVAL	
This permit is being issued with the understanding that the following conditions are met:	
Approved with the following conditions: X/ X// X/20 X2/ X23, X27, 436, 33,34	35-3
 ∴ This permit does not excuse the applicant from meeting applicable State and Federal rules and laws. Before concrete for foundation is placed, approvals from the Development Review Coordinator and Inspection Services must be (A 24 hour notice is required prior to inspection) 	obtained
3. Foundation drain shall be placed around the perimeter of a foundation that consists of gravel or crushed stone containing not mo 10 percent material that passes through a No. 4 sieve. The drain shall extend a minimum of 12 inches beyond the outside edge footing. The thickness shall be such that the bottom of the drain is not higher than the bottom of the base under the floor, and the top of the drain is not less than 6 inches above the top of the footing. The top of the drain shall be covered with an approved filt	of the nat the ter
membrane material. Where a drain tile or perforated pipe is used, the invert of the pipe or tile shall not be higher than the floor elevation. The top of joints or top of perforations shall be protected with an approved filter membrane material. The pipe or tile placed on not less than 2" of gravel or crushed stone, and shall be covered with not less than 6" of the same material. Section 18 Foundations anchors shall be a minimum of ½" in diameter, 7" into the foundation wall, minimum of 12" from corners of foundations.	e shall be 313.5.2
a maximum 6' o.c. between bolts. (Section 2305.17) Waterproofing and damp proofing shall be done in accordance with Section 1813.0 of the building code.	
 6. Precaution must be taken to protect concrete from freezing. Section 1908.0 7. It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed. This is done to 	verify
that the proper setbacks are maintained. 8. Private garages located beneath habitable rooms in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be separated from adjace interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire resisting rating. garages attached side-by-side to rooms in the above occupancies shall be completely separated from the interior spaces and the aby means of ½ inch gypsum board or the equivalent applied to the garage means of ½ inch gypsum board or the equivalent applied garage side. (Chapter 4, Section 407.0 of the BOCA/1996)	<u>Private</u> ttic area
9. All chimneys and vents shall be installed and maintained as per Chapter 12 of the City's Mechanical Code. (The BOCA National Mechanical Code/1993). Chapter 12 & NFPA 211	11
10. Sound transmission control in residential building shall be done in accordance with Chapter 12, Section 1214.0 of the City's Building.	lding
Guardrails & Handrails: A guardrail system is a system of building components located near the open sides of elevated walking so for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level. Minimum height a Groups 42", except Use Group R which is 36". In occupancies in Use Group A, B, H-4, I-1, I-2, M and R and public garages and parking structures, open guards shall have balusters or be of solid material such that a sphere with a diameter of 4" cannot pass the any opening. Guards shall not have an ornamental pattern that would provide a ladder effect. (Handrails shall be a minimum of not more than 38". Use Group R-3 shall not be less than 30", but not more than 38".) Handrail grip size shall have a circular cross with an outside diameter of at least 1 1/4" and not greater than 2". (Sections 1021 & 1022.0) - Handrails shall be on both sides of	ill Use l open hrough 3e4" but s section
stairway. (Section 1014.7) Headroom in habitable space is a minimum of 7'6". (Section 1204.0) Stair construction in <u>Use Group R-3 & R-4 is a minimum of 10" tread and 7 %" maximum rise</u> . All other Use Group minimu tread, 7" maximum rise. (Section 1014.0)	ım 11"
14. The minimum headroom in all parts of a stairway shall not be less than 80 inches. (6'8") 1014.4 15. Every sleeping room below the fourth story in buildings of Use Groups R and I-1 shall have at least one operable window or extendable from the inside without the use of special knowledge or separable from the inside without the use of special knowledge or separable from the inside without the use of special knowledge or separable from the inside without the use of special knowledge or separable from the inside without the use of special knowledge or separable from the inside without the use of special knowledge or separable from the inside without the use of special knowledge or separable from the inside without the use of special knowledge or separable from the inside without the use of special knowledge or separable from the inside without the use of special knowledge or separable from the inside without the use of special knowledge or separable from the inside without the use of special knowledge or separable from the inside without the use of special knowledge or separable from the inside without the use of special knowledge or separable from the inside without the use of special knowledge or separable from the inside without the use of special knowledge or separable from the inside without the use of special knowledge or separable from the inside without the use of special knowledge or separable from the inside without the use of special knowledge or separable from the inside without the use of special knowledge or separable from the inside without the use of special knowledge or separable from the inside without the use of special knowledge or separable from the inside without the use of special knowledge or separable from the inside without the use of special knowledge or separable from the inside without the use of special knowledge or separable from the inside without the use of special knowledge or separable from the inside with the use of special knowledge or separable from the inside with the use	Jaiaco
tools. Where windows are provided as means of egress or rescue they shall have a sill height not more than 44 inches (1118mm) the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm), and a minimum net clear opening of 5.	nes

directly from the apartment to the building exterior with no communications to other apartment units. (Section 1010.1) All vertical openings shall be enclosed with construction having a fire rating of at least one (1) hour, including fire doors with self 17. closer's. (Over 3 stories in height requirements for fire rating is two (2) hours.) (Section 710.0)

Each apartment shall have access to two (2) separate, remote and approved means of egress. A single exit is acceptable when it exits

(Section 1018.6)

16.

- 18. The boiler shall be protected by enclosing with (1)hour fire rated construction including fire d∞rs and ceiling, or by providing automatic extinguishment. (Table 302.1.1)
- All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the provisions of the City's Building Code Chapter 9, Section 920.3.2 (BOCA National Building Code/1996), and NFPA 101 Chapter 18 &19. (Smoke detectors shall be installed and maintained at the following locations):
 - In the immediate vicinity of bedrooms
 - In all bedrooms
 - In each story within a dwelling unit, including basements

In addition to the required AC primary power source, required smoke detectors in occupancies in Use Groups R-2, R-3 and I-1 shall receive power from a battery when the AC primary power source is interrupted. (Interconnection is required) Section 920.3.2.

A portable fire extinguisher shall be located as per NFPA #10. They shall bear the label of an approved agency and be of an approved type. (Section 921.0)

The Fire Alarm System shall maintained to NFPA #72 Standard.

The Sprinkler System shall maintained to NFPA #13 Standard.

- All exit signs, lights and means of egress lighting shall be done in accordance with Chapter 10 Section & Subsections 1023.0 & 1024.0 of the City's Building Code. (The BOCA National Building Code/1996)
- 24. Section 25-135 of the Municipal Code for the City of Portland states, "No person or utility shall be granted a permit to excavate or open any street or sidewalk from the time of November 15 of each year to April 15 of the following year".
- The builder of a facility to which Section 4594-C of the Maine State Human Rights Act Title 5 MRSA refers, shall obtain a certification from a design professional that the plans commencing construction of the facility, the builder shall submit the certification the Division of Inspection Services.
- 26. Ventilation shall meet the requirements of Chapter 12 Sections 1210.0 of the City's Building Code. (Crawl spaces & attics).
- All electrical, plumbing and HVAC permits must be obtained by a Master Licensed holders of their trade. No closing in of walls until all electrical (min. 72 hours notice) and plumbing inspections have been done.
- 28. All requirements must be met before a final Certificate of Occupancy is issued.
- 29. All building elements shall meet the fastening schedule as per Table 2305.2 of the City's Building Code (the BOCA National Building Code/1996).
- Ventilation of spaces within a building shall be done in accordance with the City's Mechanical Code (The BOCA National Mechanical Code/1993). (Chapter M-16)
 - 31. Please read and implement the attached Land Use Zoning report requirements.
 - 32. Boring, cutting and notching shall be done in accordance with Sections 2305.4.4, 2305.5.1 and 2305.5.3 of the City's Building Code.

Glass and glazing shall meet the requirements of Chapter 24 of the building code.

All EXIT access passage ways and Conviders shall provide clinec Toonnes, of to, exils in opposite directions From any point without a deud-end travelos of Vertical Shafts Shall meet the requirements of Section 710,0 of the building Code for trations in Fire resistance rated and a ssembles shall meet the requirement of Section 7140 of The City's building Code

Somuel Hoffses, Building Inspector Lt. McDougall, PFD

Marge Schmuckal, Zoning Administrator

PSH 12-12-98 & YMS

**On the basis of plans submitted and conditions placed on these plans any deviations shall require a separate approval.