CITY OF PORTLAND DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

389 Congress Street Portland, Maine 04101

Inspection Violations

Owner/Manager				Inspector		Inspection Date	
Grantwey Apartments Limited						5/6/1997	
Locatation CBL			Status		Inspection Type		
8 Weymouth St 053 1019001			Green 0-4 Violations		Housing-Housing Inspection		
	Code	Int/Ext		Floor	Unit No.	Area	Compliance Date
1)	6-108.2	INT					
	Violation:						
	Notes:	1ST FLR - APT #1 BATHROOM TUB WALL IS MISSING CERAMIC TILES					
2)	6-108.4	EXT					
	Violation:						
	Notes:	REAR STAI	RS STRINGER	NEEDS SUPPORT (ON OUTSIDE	CORNER	
3)	6-113.5	INT					
	Violation:						
	Notes:	OVERALL HARD-WIRED BATTERY-BACK/UP SMOKE DETECTORS ARE REQUIRED IN EACH UNIT - PERMIT BY MASTER ELECTRICIAN					
Comments: Letter Info: 5/6/97: N O H C							