

PLAN

NOTE: ALL PENETRATIONS, OPENINGS, ETC. IN PARTITION (ABOVE CEILING) TO BE FILLED W/ INSUL. AND SEALANT (AROUND) AS REQ'D @ FIRE AND ACOUSTICAL RATED PARTITIONS TO MAINTAIN RATING.

COLUMN ENCLOSURE	
2-HR RATED	UL # X528

D3 COLUMN ENCLOSURE
1 1/2" = 1'-0"



PLAN

8" CMU	
1 HR RATED - UL # U905	M76

SECTION

D2 PARTITION TYPE
1 1/2" = 1'-0"



PLAN

3 5/8" STEEL STUDS W/ 3 1/2" S.A.B.	413
NON-RATED	
6" STEEL STUDS W/ 6" S.A.B.	416
NON-RATED	

SECTION

D1 PARTITION TYPE
1 1/2" = 1'-0"



PLAN

2 1/2" C-H STUDS	332
2-HR RATED	UL # U438

SECTION

C4 SHAFT WALL
1 1/2" = 1'-0"



PLAN

NOTE: ALL PENETRATIONS, OPENINGS, ETC. IN PARTITION (ABOVE CEILING) TO BE FILLED W/ INSUL. AND SEALANT (AROUND) AS REQ'D @ FIRE AND ACOUSTICAL RATED PARTITIONS TO MAINTAIN RATING.

3 5/8" STEEL STUDS	713
2-HR RATED	UL # U495

SECTION

C3 PARTITION TYPE
1 1/2" = 1'-0"



PLAN

8" CMU	M68
2 HR RATED - UL # U905	
4" CMU	M64
NON- RATED	

SECTION

C2 PARTITION TYPE
1 1/2" = 1'-0"



PLAN

3 5/8" STEEL STUDS	113
NON-RATED	

SECTION

C1 PARTITION TYPE
1 1/2" = 1'-0"



FLOOR/CEILING ASSEMBLY - 2 HOUR SIM TO UL-6222

B4
1/2" = 1'-0"



EXTERIOR METAL SIDING	W02
NON-RATED	

B3 EXTERIOR WALL SYSTEM
1 1/2" = 1'-0"



PLAN

8" CMU	M58
2 HR RATED - UL # U905	

SECTION

B2 PARTITION TYPE
1 1/2" = 1'-0"



PLAN

3 5/8" STEEL STUDS	213
NON-RATED	
6" STEEL STUDS	216
NON-RATED	
6" STEEL STUDS	218
NON-RATED	

SECTION

B1 PARTITION TYPE
1 1/2" = 1'-0"



CMU WITH EXTERIOR METAL SIDING	W03
NON-RATED	

A4 EXTERIOR WALL SYSTEM
1 1/2" = 1'-0"



STEEL STUDS W EXTERIOR WOOD SIDING	W01
NON-RATED	
STEEL STUDS W EXTERIOR WOOD SIDING	W01
1-HR RATED	UL # U465 (SIM)

A3 EXTERIOR WALL SYSTEM
1 1/2" = 1'-0"



PLAN

3 5/8" STEEL STUDS	233
NON-RATED	
6" STEEL STUDS	236
NON-RATED	

SECTION

A2 PARITION TYPE
1 1/2" = 1'-0"

GENERAL NOTES

1.) SEE DRAWING A40.1 FOR PARTITION CONNECTION DETAILS.

2.) SEE SECTIONS AND DETAILS FOR CONNECTIONS OTHER THAN THOSE NOTED ON DRAWING A40.1.

3.) IN TOILET ROOMS, PROVIDE 5/8" MR GPDW TO 8" ABOVE CEILING IN LIEU OF REGULAR GPDW ON ALL STEEL STUD PARTITIONS WITHIN THE ROOM. USE REGULAR 5/8" GPDW ABOVE MR GPDW TO TOP OF PARTITION.

4.) ALL 1 HR OR 2 HR FIRE RATED WALLS SHALL BE STENCILED ON THE WALL SURFACE JUST ABOVE THE CEILING LINE INDICATING THE WALL'S FIRE RATING; "1 HR", "2 HR", ETC. IN RED OR ORANGE PAINT ON EACH SIDE OF THE PARTITION.

5.) WHERE BATT INSULATION IS SHOWN FILL STUD CAVITY FULL.



A1 PARTITION LEGEND
1 1/2" = 1'-0"

Architects + Engineers

HARRIMAN ASSOCIATES

One Auburn Business Park
Auburn, ME 04210
PH: 207.784.5100
Fax: 207.782.3017

66 Pearl Street, Suite 301
Portland, ME 04101
PH: 207.784.5100
Fax: 207.775-0460

Maine Heart Surgical Associates

New Office Building

Portland, ME

Project Number 04180

Key Plan



General Notes:

No.	Description	Date
	ISSUED FOR BID	4-28-05

Drawing Status:

Construction Systems

Issue Date: 04-28-05

Drawn By: JGJ

PA / PE: PSC

A40.1

Scale As indicated

4/28/2005 2:46:46 PM