



KEY NOTES:
 L01... MINIMUM WIRE SIZE SHALL BE #10 A.W.G. SEE DETAIL (LIGHTING CONTROLS) ON DRAWING E10.1 FOR CIRCUITING. CONDUITS SHALL BE CONCEALED FOR ENTRYWAY LIGHTING AND TWO TYPE K LIGHTING FIXTURES ON SECOND LEVEL PARKING.
 L06... COORDINATE LIGHTING FIXTURES WITH MECHANICAL PIPING, DUCT WORK AND EQUIPMENT.
 P05... CEILING SPACE ABOVE THE SECOND FLOOR PARKING LEVEL IS USED AS AN AIR PLENUM.

Mark	Date	Description
-	04-28-05	ISSUED FOR BID
-	04-11-05	100% REVIEW
-	01-10-05	DD REVIEW

Issue Dates

Drawing Title
**SECOND FLOOR
 PLAN - LIGHTING**

PA / PE: **PRM** Drawn By: **JMB/KRM**
 Drawing Number

E10.2

