

## SECTION 07842

### FIRE-RESISTIVE JOINT SYSTEMS

#### PART 1 - GENERAL

##### 1.01 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

##### 1.02 SUMMARY

- A. This Section includes fire-resistive joint systems for the following:
  - 1. Floor-to-floor joints.
  - 2. Floor-to-wall joints.
  - 3. Head-of-wall joints.
  - 4. Wall-to-wall joints.
  - 5. Wall-to-adjacent structure and supports.
- B. Related Sections include the following:
  - 1. Division 7 Section "Through-Penetration Firestop Systems" for systems installed in openings in walls and floors with and without penetrating items.
  - 2. Division 7 Section "Joint Sealants" for non-fire-resistive joint sealants.
  - 3. Division 9 Section "Gypsum Board Assemblies" for firestopping where fire rated gypsum board assemblies butting adjacent construction including masonry, steel deck, joists, beams, floors, roofs and structural members.

##### 1.03 PERFORMANCE REQUIREMENTS

- A. General: Provide fire-resistive joint systems that are produced and installed to resist spread of fire according to requirements indicated, resist passage of smoke and other gases, and maintain original fire-resistance rating of assembly in which fire-resistive joint systems are installed.
- B. Joint Systems in and between Fire-Resistance-Rated Constructions: Provide systems with assembly ratings equaling or exceeding the fire-resistance ratings of construction that they join, and with movement capabilities and L-ratings as determined by UL 2079.
  - 1. For fire-resistance systems with movement capabilities, allow for the following movement.
    - a. Floors: 1/2-inch deflection.
    - b. Roofs: 1 1/2-inch deflection.
  - 2. Provide systems with L-rating where walls and partitions also are smoke barriers. Where fire-resistive joint system is not available with the ability to resist smoke, provide smoke sealant material to one side of wall to stop the passage of smoke.

##### 1.04 SUBMITTALS

- A. General: Submit in accordance with Section 01300.
- B. Product Data: For each type of product proposed for use.
- C. Shop Drawings: For each fire-resistive joint system, show each kind of construction condition in which joints are installed; also show relationships to adjoining construction. Include fire-resistive joint system UL design designation of testing and inspecting agency acceptable to authorities having jurisdiction that demonstrates compliance with requirements for each condition indicated.

1. Submit documentation, including illustrations, from a qualified testing and inspecting agency that is applicable to each fire-resistive joint system configuration for construction and penetrating items.

D. Research/Evaluation Reports: For each type of fire-resistive joint system.

#### 1.05 QUALITY ASSURANCE

A. Source Limitations: Obtain fire-resistive joint systems, for each kind of joint and construction condition indicated, through one source from a single manufacturer.

B. Fire-Test-Response Characteristics: Provide fire-resistive joint systems that comply with the following requirements and those specified in Part 1 "Performance Requirements" Article:

1. Fire-resistance tests are performed by a qualified testing and inspecting agency. Qualified testing and inspecting agency is UL OPL or another agency performing testing and follow-up inspection services for fire-resistive joint systems acceptable to authorities having jurisdiction.
2. Fire-resistive joint systems are identical to those tested per methods indicated in Part 1 "Performance Requirements" Article and comply with the following:
  - a. Fire-resistive joint system products bear classification marking of qualified testing and inspecting agency.
  - b. Fire-resistive joint systems correspond to those indicated by referencing system designations of the qualified testing and inspecting agency.

#### 1.06 DELIVERY, STORAGE, AND HANDLING

A. Deliver fire-resistive joint system products to Project site in original, unopened containers or packages with qualified testing and inspecting agency's classification marking applicable to Project and with intact and legible manufacturers' labels identifying product and manufacturer, date of manufacture, lot number, shelf life, curing time, and mixing instructions for multicomponent materials.

B. Store and handle materials for fire-resistive joint systems to prevent their deterioration or damage due to moisture, temperature changes, contaminants, or other causes.

C. Remove and replace materials, at no cost to Owner, that cannot be applied within their stated shelf life.

#### 1.07 PROJECT CONDITIONS

A. Environmental Limitations: Do not install fire-resistive joint systems when ambient or substrate temperatures are outside limits permitted by fire-resistive joint system manufacturers or when substrates are wet due to rain, frost, condensation, or other causes.

B. Ventilate fire-resistive joint systems per manufacturer's written instructions by natural means or, if this is inadequate, forced-air circulation.

#### 1.08 COORDINATION

A. Coordinate construction of joints to ensure that fire-resistive joint systems are installed according to specified requirements.

B. Coordinate sizing of joints to accommodate fire-resistive joint systems.

### PART 2 - PRODUCTS

#### 2.01 MANUFACTURERS

A. Products: Subject to compliance with requirements, provide products by one of the following:

1. A/D Fire Protection Systems Inc.

2. W.R. Grace & Co., Construction Products Division.
3. Hilti Construction Chemicals, Inc.
4. Johns Manville International, Inc.
5. Nelson Firestop Products
6. RectorSeal Corporation (The).
7. Specified Technologies Inc.
8. 3M Fire Protection Products.
9. Tremco.
10. United States Gypsum Company.

## 2.02 FIRE-RESISTIVE JOINT SYSTEMS

- A. **Compatibility:** Provide fire-resistive joint systems that are compatible with joint substrates, under conditions of service and application, as demonstrated by fire-resistive joint system manufacturer based on testing and field experience. Fire-resistive joint systems surfaces that will remain exposed in public spaces upon completion of Work shall be paintable.
- B. **Accessories:** Provide components of fire-resistive joint systems, including primers and forming materials, that are needed to install fill materials and to comply with Part 1 "Performance Requirements" Article. Use only components specified by fire-resistive joint system manufacturer and approved by the qualified testing and inspecting agency for systems submitted.

## PART 3 - EXECUTION

### 3.01 EXAMINATION

- A. Examine substrates and conditions, with Installer present, for compliance with requirements for joint configurations, substrates, and other conditions affecting performance of work.
  1. Proceed with installation only after unsatisfactory conditions have been corrected.

### 3.02 PREPARATION

- A. **Surface Cleaning:** Clean joints immediately before installing fire-resistive joint systems to comply with fire-resistive joint system manufacturer's written instructions and the following requirements:
  1. Remove from surfaces of joint substrates foreign materials that could interfere with adhesion of fill materials.
  2. Clean joint substrates to produce clean, sound surfaces capable of developing optimum bond with fill materials. Remove loose particles remaining from cleaning operation.
  3. Remove laitance and form-release agents from concrete.
- B. **Priming:** Prime substrates where recommended in writing by fire-resistive joint system manufacturer using that manufacturer's recommended products and methods. Confine primers to areas of bond; do not allow spillage and migration onto exposed surfaces.
- C. **Masking Tape:** Use masking tape to prevent fill materials of fire-resistive joint system from contacting adjoining surfaces that will remain exposed on completion of Work and that would otherwise be permanently stained or damaged by such contact or by cleaning methods used to remove smears of fire-resistive joint system materials from adjoining surfaces. Remove tape as soon as possible without disturbing fire-resistive joint system's seal with substrates or damaging adjoining surfaces.

### 3.03 INSTALLATION

- A. **General:** Install fire-resistive joint systems to comply with Part 1 "Performance Requirements" Article and fire-resistive joint system manufacturer's written installation instructions for products and applications used.

- B. Install forming/packing/backing materials and other accessories of types required to support fill materials during their application and in position needed to produce cross-sectional shapes and depths required to achieve fire ratings indicated.
- C. Install fill materials for fire-resistive joint systems by proven techniques to produce the following results:
  - 1. Fill voids and cavities formed by openings and forming/packing/backing materials as required to achieve fire-resistance ratings indicated.
  - 2. Apply fill materials so they contact and adhere to substrates formed by joints.
  - 3. For fill materials that will remain exposed after completing Work, finish to produce smooth, uniform surfaces that are flush with adjoining finishes.

#### 3.04 FIELD QUALITY CONTROL

- A. Before installation of ceilings and adjacent construction that would conceal firestopping, inspect joints to verify complete installation of firestopping materials.
- B. Remove and replace fire-resistive joint systems where inspections indicate that they do not comply with specified requirements.

#### 3.05 CLEANING AND PROTECTING

- A. Clean off excess fill materials adjacent to joints as Work progresses by methods and with cleaning materials that are approved in writing by fire-resistive joint system manufacturers and substrate manufacturers that do not damage materials in which openings occur.
- B. Provide final protection and maintain conditions during and after installation that ensure fire-resistive joint systems are without damage or deterioration at time of Substantial Completion. If damage or deterioration occurs despite such protection, cut out and remove damaged or deteriorated fire-resistive joint systems immediately and install new materials to produce fire-resistive joint systems complying with specified requirements.

END OF SECTION