

SECTION 07920

JOINT SEALANTS

PART 1 - GENERAL

1.01 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 Specification Sections, apply to this Section.

1.02 SUMMARY

- A. This Section includes joint sealants for the following applications, including those specified by reference to this Section:
 - 1. Exterior joints in the following vertical surfaces and horizontal nontraffic surfaces:
 - a. Construction and control joints in cast-in-place concrete.
 - b. Control and expansion joints in unit masonry, new and existing.
 - c. Joints between different materials listed above.
 - d. Perimeter joints between materials listed above and frames of doors, windows, and louvers.
 - e. Control and expansion joints in ceilings and other overhead surfaces.
 - f. Other joints as indicated.
 - 2. Exterior joints in the following horizontal traffic surfaces:
 - a. Isolation and contraction joints in new cast-in-place concrete slabs.
 - b. Other joints as indicated.
 - 3. Interior joints in the following vertical surfaces and horizontal nontraffic surfaces:
 - a. Control and expansion joints on exposed interior surfaces of exterior walls.
 - b. Perimeter joints of exterior openings where indicated.
 - c. Tile control and expansion joints.
 - d. Vertical joints on exposed surfaces of interior unit masonry walls.
 - e. Perimeter joints between interior wall surfaces and frames of interior doors, windows, borrowed lites, and elevator entrances.
 - f. Joints between plumbing fixtures and adjoining walls, floors, and counters.
 - g. Joints between fiberglass reinforced wall panels.
 - h. Other joints as indicated.
 - 4. Interior joints in the following horizontal traffic surfaces:
 - a. Isolation and control joints in exposed, new cast-in-place concrete slabs.
 - b. Control and expansion joints in tile flooring.
 - c. Other joints as indicated.
 - 5. Remove and replace existing sealants and backer rods at indicated locations.
- B. Related Sections include the following:
 - 1. Division 2 Sections for sealing joints in pavements, walkways, and curbing.
 - 2. Division 4 Section "Unit Masonry Assemblies" for masonry control and expansion joint fillers and gaskets.
 - 3. Division 7 Section "Flashing and Sheet Metal" for sealing joints related to flashing.
 - 4. Division 7 Section "Through-Penetration Firestop Systems" for sealing joints around penetrations in fire-resistance-rated construction.
 - 5. Division 7 Section "Fire-Resistive Joint Systems" for sealing joints in fire-resistance-rated construction.
 - 6. Division 8 Section "Glazing" for glazing sealants.
 - 7. Division 9 Section "Gypsum Board Assemblies" for sealing perimeter joints of gypsum board partitions to reduce sound transmission and to seal for fire-resistant-rated construction.
 - 8. Division 9 Section "Tile" for sealing tile joints.
 - 9. Divisions 15 and 16 for sealing of perimeter joints of plumbing, HVAC systems, automatic fire protection systems, telecommunication systems, and electrical systems.

1.03 PERFORMANCE REQUIREMENTS

- A. Provide joint sealants that have been produced and installed to establish and to maintain watertight and airtight continuous seals without causing staining or deterioration of joint substrates.
- B. Provide joint sealants for interior applications that establish and maintain airtight and water-resistant continuous joint seals without staining or deteriorating joint substrates.

1.04 SUBMITTALS

- A. General: Submit in accordance with Section 01300.
- B. Product Data: For each joint-sealant product indicated.
- C. Samples for Selection: Manufacturer's color charts consisting of strips of cured sealants showing the full range of colors available for each product exposed to view.
- D. Qualification Data: For Installer.

1.05 QUALITY ASSURANCE

- A. Installer Qualifications: Engage an experienced Installer who has completed joint sealant applications similar in materials, design, and extent to that indicated for Project that have resulted in construction with a record of successful in-service performance.
- B. Source Limitations: Obtain each type of joint sealant through one source from a single manufacturer.

1.06 DELIVERY, STORAGE, AND HANDLING

- A. Deliver materials to Project site in original unopened containers or bundles with labels indicating manufacturer, product name and designation, color, expiration period for use, shelf/pot life, curing time, and mixing instructions for multi-component materials.
- B. Store and handle materials in compliance with manufacturer's recommendations to prevent their deterioration or damage due to moisture, high or low temperatures, contaminants, or other causes.
- C. Remove and replace materials, at no cost to Owner, which cannot be applied within their stated shelf life.

1.07 PROJECT CONDITIONS

- A. Environmental Conditions: Do not proceed with installation of joint sealants under the following conditions:
 - 1. When ambient and substrate temperature conditions are outside limits permitted by joint-sealant manufacturer or are below 40 deg F.
 - 2. When joint substrates are wet.
 - 3. Where joint widths are less than those allowed by joint-sealant manufacturer for applications indicated.
 - 4. Contaminants capable of interfering with adhesion have not yet been removed from joint substrates.
- B. Joint Width Conditions: Do not proceed with installation of joint sealants where joint widths are less than allowed by joint sealant manufacturer for application indicated.
- C. Joint Substrate Conditions: Do not proceed with installation of joint sealants until contaminants capable of interfering with their adhesion are removed from joint substrates.

1.08 SEQUENCING AND SCHEDULING

- A. Coordinate Work of this Section with interfacing and adjoining Work for proper sequencing of each installation to ensure a weathertight installation.

PART 2 - PRODUCTS

2.01 MANUFACTURERS

- A. Products: Subject to compliance with requirements, provide one of the products listed in other Part 2 articles.

2.02 MATERIALS, GENERAL

- A. Compatibility: Provide joint sealants, backings, and other related materials that are compatible with one another and with joint substrates under conditions of service and application, as demonstrated by sealant manufacturer, based on testing and field experience.
- B. Colors of Exposed Joint Sealants: As selected by Architect from manufacturer's full range.

2.03 JOINT SEALANTS

- A. Type 1 - General Purpose Exterior Sealant: Polyurethane; ASTM C920, Type S, Grade NS, Class 25; single component.
 - 1. Sonolastic NP-1; Sonneborn, Division of ChemRex Inc.
 - 2. Dymonic; Tremco.
 - 3. Sikaflex-1a; Sika Corporation, Inc.
 - 4. Dynatrol 1; Pecora Corporation.
 - 5. Vulkem 921; Tremco.
 - 6. Chem-Calk 900; Bostik Findley.
- B. Type 2 - General Purpose Exterior Sealant: Polyurethane; ASTM C920, Type M, Grade NS, Class 25; two-component.
 - 1. Sonolastic NP-2; Sonneborn, Division of ChemRex Inc.
 - 2. Dymeric; Tremco.
 - 3. Sikaflex-2c, NS; Sika Corporation, Inc.
 - 4. Dynatrol 2; Pecora Corporation.
 - 5. Vulkem 922; Tremco.
 - 6. Chem-Calk 500; Bostik Findley.
- C. Type 3 - General Purpose Interior Sealant: Acrylic emulsion latex; ASTM C834, single component, paintable.
 - 1. Tremco Acrylic Latex; Tremco.
 - 2. AC-20; Pecora Corporation.
 - 3. Chem-Calk 600; Bostik Findley.
- D. Type 4 - Plumbing Fixture/Tile Sealant: Silicone; ASTM C920, Uses M and A; single component, mildew resistant, color selected by Architect.
 - 1. Sanitary 1700; GE Silicones.
 - 2. 898 Silicone; Pecora Corporation.
 - 3. 786 MR Silicone; Dow Corning Corporation.
- E. Type 5 - Acoustical Sealant: Not Used.
- F. Type 6 - Interior Floor Joint Sealant: Polyurethane, self-leveling; ASTM C920, Grade P, Class 25, Uses T, M and A; single component.
 - 1. Sonolastic SL-1; Sonneborn, Division of ChemRex Inc.
 - 2. Tremflex S/L; Tremco.

3. Sikaflex-1CSL; Sika Corporation, Inc.
4. NR-201; Pecora Corporation.
5. Vulkem 45; Tremco.
6. Chem-Calk 950; Bostik Findley.

2.04 JOINT-SEALANT BACKING

- A. General: Provide sealant backings of material and type that are nonstaining; are compatible with joint substrates, sealants, primers, and other joint fillers; and are approved for applications indicated by sealant manufacturer based on field experience and laboratory testing.
- B. Plastic Foam Joint-Sealant Backing (Backer Rod): Preformed, compressible, resilient, nonstaining, nonwaxing, nonextruding strips of flexible plastic foam of material indicated below and of size, shape, and density to control sealant depth and otherwise contribute to producing optimum sealant performance:
 1. Closed-cell polyethylene foam, nonabsorbent to liquid water and gas, nonoutgassing in unruptured state.
- C. Bond-Breaker Tape: Polyethylene tape or other plastic tape recommended by sealant manufacturer for preventing sealant from adhering to rigid, inflexible joint-filler materials or joint surfaces at back of joint where such adhesion would result in sealant failure. Provide self-adhesive tape where applicable.

2.05 MISCELLANEOUS MATERIALS

- A. Primer: Material recommended by joint-sealant manufacturer where required for adhesion of sealant to joint substrates indicated, as determined from preconstruction joint-sealant-substrate tests and field tests.
- B. Cleaners for Nonporous Surfaces: Chemical cleaners acceptable to manufacturers of sealants and sealant backing materials, free of oily residues or other substances capable of staining or harming joint substrates and adjacent nonporous surfaces in any way, and formulated to promote optimum adhesion of sealants to joint substrates.
- C. Masking Tape: Nonstaining, nonabsorbent material compatible with joint sealants and surfaces adjacent to joints.

PART 3 - EXECUTION

3.01 EXAMINATION

- A. Examine joints indicated to receive joint sealants, with Installer present, for compliance with requirements for joint configuration, installation tolerances, and other conditions affecting joint-sealant performance.
- B. Proceed with installation only after unsatisfactory conditions have been corrected.

3.02 PREPARATION

- A. Surface Cleaning of Joints: Clean out joints immediately before installing joint sealants to comply with joint-sealant manufacturer's written instructions and the following requirements:
 1. Remove all foreign material from joint substrates that could interfere with adhesion of joint sealant, including dust, paints (except for permanent, protective coatings tested and approved for sealant adhesion and compatibility by sealant manufacturer), old joint sealants, oil, grease, waterproofing, water repellents, water, surface dirt, and frost.
 - a. Existing Joints: At existing joints indicated to receive new sealants, remove existing backer rod and sealant. Clean existing surfaces of all existing sealant and other foreign materials that could interfere with adhesion of new joint sealant.
 2. Clean concrete, masonry unglazed surfaces of ceramic tile, and similar porous joint substrate surfaces by brushing, grinding, blast cleaning, mechanical abrading, or a combination of these methods to produce a clean, sound substrate capable of developing optimum bond with joint

- sealants. Remove loose particles remaining after cleaning operations above by vacuuming or blowing out joints with oil-free compressed air.
3. Remove laitance and form-release agents from concrete.
 4. Clean metal, glass, porcelain enamel, glazed surfaces of ceramic tile, and other nonporous surfaces with chemical cleaners or other means that do not stain, harm substrates, or leave residues capable of interfering with adhesion of joint sealants.

- B. **Joint Priming:** Prime joint substrates, where indicated or recommended in writing by joint-sealant manufacturer, based on preconstruction joint-sealant-substrate tests or prior experience. Apply primer to comply with joint-sealant manufacturer's written instructions. Confine primers to areas of joint-sealant bond; do not allow spillage or migration onto adjoining surfaces.
- C. **Masking Tape:** Use masking tape where required to prevent contact of sealant with adjoining surfaces that otherwise would be permanently stained or damaged by such contact or by cleaning methods required to remove sealant smears. Remove tape immediately after tooling without disturbing joint seal.

3.03 INSTALLATION OF JOINT SEALANTS

- A. **General:** Comply with joint-sealant manufacturer's written installation instructions for products and applications indicated, unless more stringent requirements apply.
- B. **Sealant Installation Standard:** Comply with recommendations in ASTM C 1193 for use of joint sealants as applicable to materials, applications, and conditions indicated.
- C. **Installation of Sealant Backings (Backer Rods):** Install sealant backings to comply with the following requirements:
 1. Install sealant backings of type indicated to provide support of sealants during application and at position required to produce cross-sectional shapes and depths of installed sealants relative to joint widths that allow optimum sealant movement capability.
 - a. Do not leave gaps between ends of sealant backings.
 - b. Do not stretch, twist, puncture, or tear sealant backings.
 2. Install bond-breaker tape behind sealants where sealant backings are not used between sealants and backs of joints.
- D. **Installation of Sealants:** Install sealants using proven techniques that result in sealants directly contacting and fully wetting joint substrates, completely filling recesses provided for each joint configuration, and providing uniform, cross-sectional shapes and depths relative to joint widths that allow optimum sealant movement capability. Install sealants at same time sealant backings are installed.
- E. **Tooling of Nonsag Sealants:** Immediately after sealant application and before skinning or curing begins, tool sealants according to requirements specified below to form smooth, uniform beads of configuration indicated; to eliminate air pockets; and to ensure contact and adhesion of sealant with sides of joint.
 1. Remove excess sealant from surfaces adjacent to joints.
 2. Use tooling agents that are approved in writing by sealant manufacturer and that do not discolor sealants or adjacent surfaces.
 3. Provide concave joint configuration per Figure 5A in ASTM C 1193, unless otherwise indicated.

3.04 CLEANING

- A. Clean off excess sealant or sealant smears adjacent to joints as the Work progresses by methods and with cleaning materials approved in writing by manufacturers of joint sealants and of products in which joints occur.

3.05 PROTECTION

- A. Protect joint sealants during and after curing period from contact with contaminating substances and from damage resulting from construction operations or other causes so sealants are without deterioration or damage at time of Substantial Completion. If, despite such protection, damage or deterioration occurs,

cut out and remove damaged or deteriorated joint sealants immediately so installations with repaired areas are indistinguishable from original work.

3.06 JOINT-SEALANT SCHEDULE

- A. Control, Expansion, and Soft Joints in Masonry and Between Masonry and Adjacent Work: Type 2; colors as selected.
- B. Joints between Exterior Metal Frames and Adjacent Work (except masonry): Type 2; colors as selected.
- C. Under Exterior Door Thresholds: Type 1.
- D. Exterior Joints for Which No Other Sealant Type is Indicated: Type 2; colors as selected.
- E. Concealed Interior Perimeter Joints of Exterior Openings: Type 1.
- F. Exposed Interior Perimeter Joints of Exterior Openings: Type 3; colors as selected.
- G. Interior Ceramic Tile Expansion, Control, Contraction, and Isolation Joints in Horizontal Traffic Surfaces: Type 2; color as selected.
- H. Control and Expansion Joints in Interior Concrete Slabs and Floors Left Exposed: Type 6; colors as selected.
- I. Joints between Plumbing Fixtures and Walls and Floors and Between Countertops and Walls: Type 4; colors as selected.
- J. Interior Joints for Which No Other Sealant is Indicated: Type 3; colors as selected.

END OF SECTION