

# 354 876

Portland, Maine



Yes. Life's good here.

August 12, 2015

S & A 786 Holding Llc

754 Congress St

Portland, ME 04102

CBL: 054 G001001

Located at 754 CONGRESS ST

#### NOTICE OF INTENT TO PROSECUTE

Dear Owner/Manager/Occupant,

An inspection of the property located at the address referenced above revealed that the structure and premises fail to comply with NFPA 2009 Fire Code and/or NFPA Life Safety Codes. Attached is a list of those violations.

The above-referenced property is in violation of the Chapter 10, Fire Prevention and Protection, Article 1 of the Portland City Code (the "Code") and National Fire Protection Association (NFPA) 101 Life Safety Code. Please note that the Code is available online at [www.portlandmaine.gov](http://www.portlandmaine.gov).

This is a notice of intent to prosecute. As such, the matter is being referred to the City of Portland Corporation Council for legal action and possible civil penalties as provided for in Chapter 10, Fire Prevention and Protection, 10-25 of the Code and in Title 30- A.M.R.S.A. 4452.

Please be advised that you will need to contact the Fire Prevention Bureau at 207-874-8400 before the court date on the attached Reference to Court letter to either schedule a re-inspection or to submit a plan of action to correct these violations.

Sincerely,

A handwritten signature in cursive script that reads "A/C Keith Sturtevant".

Portland Fire Department

Fire Prevention Bureau

---

---

**CITY OF PORTLAND  
PORTLAND FIRE DEPARTMENT**

380 Congress Street  
Portland, Maine 04101

---

**Inspection Violations**

<b>Owner/Manager</b> S & A 786 Holding Llc		<b>Inspector</b> Kevin Henry		<b>Inspection Date</b> 8/11/2015	
<b>Location</b> 754 CONGRESS ST	<b>CBL</b> 054 G001001	<b>Status</b> Failed		<b>Inspection Type</b> Fire Prevention-FP Permit	

---

<b>Code</b>	<b>Int/Ext</b>	<b>Floor</b>	<b>Unit No.</b>	<b>Area</b>	<b>Compliance Date</b>
-------------	----------------	--------------	-----------------	-------------	------------------------

---

1) 8.027

**Violation:** NFPA 1- 4.5.8.1 FIRE PROTECTION SYSTEM OUT OF SERV.; Whenever or wherever any device, equipment, system, condition, arrangement, level of protection, fire-resistive construction, or any other feature is required for compliance with the provisions of this code, such device, equipment, system, condition, arrangement, level of protection, fire-resistive construction, or other feature shall thereafter be continuously maintained. Maintenance shall be provided in accordance with applicable NFPA requirements or requirements developed as part of a performance-based design, or as directed by the AHJ.

**Notes:** FUEL ISLAND AND KITCHEN HOOD SYSTEM REQUIRE SERVICE AND ANNUAL INSPECTION TAG

---

**Comments:**

STATE OF MAINE

DISTRICT COURT  
Location: Portland  
Docket No.

CITY OF PORTLAND and body politic and  
Corporate, located in the County of  
Cumberland and State of Maine,

Plaintiff,

v.

S & A 786 Holding LLC  
Defendant


**FIRE PREVENTION AND PROTECTION  
CODE VIOLATION**

**(M.R. CIV. P. 80H AND 80k)**

SUMMONS NUMBER: 354876

This matter has been referred to the Corporation Counsel's Office for immediate legal action with respect to the code violations detailed in the attached letter. It has been assigned the above summons number and will be filed with the Portland District Court and will be assigned for an initial appearance at the Portland District Court 205 Newbury Street Portland, Maine 04101 at 8:30 A.M. on 09/14/2015. I strongly urge you to contact Victoria Meserve at Fire Prevention at (207)-874-8400 or via e-mail at [meservev@portlandmaine.gov](mailto:meservev@portlandmaine.gov) to set up an in-person meeting to resolve these issues or make alternative arrangements to relieve you of the requirement to appear in Court on 09/14/2015.

Dated: 8/17/15



---

Adam R. Lee, Esq. Bar No. 4143  
Associate Corporation Council  
City of Portland  
389 Congress St  
Portland, ME 04101  
207-874-8480