Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 07/12/13

Life Safety Information

Bakery Project - 742 Congress Street Portland

- Two means of egress through existing unrated storefront doors.
- Maximum travel distance to exit 55'-0".
- One centrally located fire extinguisher.
- Emergency lighting above exit doors.
- Lighted exit signs above exit doors.
- Single story, F-1 single use, independent structure with fire separation >5'-0", IIIB construction.