


CITY OF PORTLAND  
 FIRE PREVENTION BUREAU  
 380 Congress Street, Portland, Maine 04101  
 fireprevention@portlandmaine.gov  
 (207) 874-8400



**NOTICE OF VIOLATION AND ORDER TO CORRECT**

December 8, 2016

|   |   |                                      |
|---|---|--------------------------------------|
| <b>Responsible Party 1:</b><br>M P Burnham Properties<br>PO BOX 2282<br>SCARBOROUGH, ME 04070 |   |                                      |
| <b>Location</b><br>88 CARLETON ST   | <b>CBL</b><br>054 G008001                       | <b>Inspection Date</b><br>11/26/2016 |
| <b>Inspector</b><br>Edward Dexter, Jr.  | <b>Inspection Type</b><br>FP Routine Inspection | <b>Status</b><br>Failed              |

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must complete the proposed date of completion column by proposing a reasonable timeframe to remedy each violation. This form must be received by the Fire Prevention Bureau no later than 12/30/2016. The Bureau reserves the right to reject or modify any proposed plan of action, and may require evidence of sufficient financial and technical capacity to complete the proposed plan. Please contact the Bureau with any questions.

**YOUR FAILURE TO SUBMIT A PLAN OF ACTION BY THE DATE PROVIDED, OR TO CORRECT ANY VIOLATION WITHIN THE APPLICABLE TIME FRAME, MAY RESULT IN LEGAL ACTION AGAINST YOU, THE IMPOSITION OF CIVIL PENALTIES, AND THE PURSUIT OF OTHER LEGAL REMEDIES.**

| <b>Violation</b>  | <b>Proposed Date of Completion</b> |
|---|------------------------------------|
| <b>PORTLAND FIRE DEPARTMENT CHAPTER 10 SECTION 12 KNOX BOX REQUIRED;</b><br>Knox Boxes are required for all buildings with fire alarm or suppression systems. | 2/28/17                            |

**VIOLATOR CERTIFICATION**

I agree to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau prior to the deadline to request an extension, which is entirely within the Bureau's discretion to grant or deny.

I further understand that it is my responsibility to schedule a reinspection of my property once the violations have been remedied to do so. My failure to schedule a reinspection shall be deemed an admission that the violations have not been remedied.

If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.

1-6-17                      [Signature] Colletti  
Date                                      Responsible Party

\_\_\_\_\_  
Date                                      Responsible Party

**SEEN AND AGREED**

1-6-17                      Katherine Cochran for Capt. Petrucci  
Date                                      Fire Prevention Bureau

Lenny Colello                      615-5559

88 CARLETON ST.