

**. . . Fire Protection by Computer Design**

FREEDOM FIRE PROTECTION INC.  
209 QUAKER RIDGE ROAD  
CASCO, MAINE 04015  
207-627-4109

Job Name : 171 & 169 NEAL STREET HC2  
Building : 171 & 169 NEAL STREET  
Location : PORTLAND, MAINE 04102  
System : #1 AREA #2  
Contract :  
Data File : 171 & 169 NEAL STREET HC2.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - 171 & 169 NEAL STREET Date - 12/17/12  
Location - PORTLAND, MAINE 04102  
Building - 171 & 169 NEAL STREET System No. - #1 AREA #2  
Contractor - FREEDOM FIRE PROTECTION Contract No. -  
Calculated By - MICHAEL NOBLIT Drawing No. - FP-3  
Construction: (X) Combustible ( ) Non-Combustible Ceiling Height 8'-7"  
OCCUPANCY - APARTMENT

S Type of Calculation: (X)NFPA 13 Residential (X)NFPA 13R ( )NFPA 13D  
Y Number of Sprinklers Flowing: ( )1 ( )2 (X)4 ( )  
S ( )Other  
T ( )Specific Ruling Made by Date  
E  
M Listed Flow at Start Point - 14 Gpm System Type  
Listed Pres. at Start Point - 10.1 Psi (X) Wet ( ) Dry  
D MAXIMUM LISTED SPACING 14' x 14' ( ) Deluge ( ) PreAction  
E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle  
S Additional Flow Added - 0 Gpm Make TYCO Model LFII  
I Elevation at Highest Outlet - 27'-9"Feet Size 1/2" K-Factor 4.4  
G Note: Temperature Rating 155  
N

Calculation Gpm Required 56.227 Psi Required 48.712 At Test  
Summary C-Factor Used: Overhead 120 Underground 140

W Water Flow Test: Pump Data: Tank or Reservoir:  
A Date of Test - 8/16/2008 Rated Cap. Cap.  
T Time of Test - @ Psi Elev.  
E Static (Psi) - 55 Elev.  
R Residual (Psi) - 0 Other Well  
Flow (Gpm) - 1186 Proof Flow Gpm  
S Elevation -

P Location:  
P  
L Source of Information: PORTLAND WATER DISTRICT  
Y


# Water Supply Curve (C)

FREEDOM FIRE PROTECTION INC.  
171 & 169 NEAL STREET HC2

Page 2  
Date 12/17/12

City Water Supply:  
C1 - Static Pressure : 55  
C2 - Residual Pressure: 0  
C2 - Residual Flow : 1186

Demand:  
D1 - Elevation : 12.019  
D2 - System Flow : 56.2272  
D2 - System Pressure : 48.712  
Hose ( Adj City ) : \_\_\_\_\_  
Hose ( Demand ) : \_\_\_\_\_  
D3 - System Demand : 56.2272  
Safety Margin : 6.092



# Fittings Used Summary

FREEDOM FIRE PROTECTION INC.  
171 & 169 NEAL STREET HC2

Page 3  
Date 12/17/12

Fitting Legend

Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
T	90' Flow Thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Zaa	Ames 2000B	Fitting generates a Fixed Loss Based on Flow																			

Pressure / Flow Summary - STANDARD

FREEDOM FIRE PROTECTION INC.  
171 & 169 NEAL STREET HC2

Page 4  
Date 12/17/12

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
204	27.75		10.34	na				
203	27.75	4.4	10.1	na	13.99	0.05	0.001	10.1
202	27.75	4.4	10.1	na	13.98	0.05	0.001	10.1
201	27.75	4.4	10.28	na	14.11	0.05	0.001	10.1
20	27.75		11.67	na				
7	27.75		12.7	na				
6	16.66		19.05	na				
5	16.66		19.79	na				
4	6.166		25.92	na				
3	6.166		27.94	na				
2	6.166		29.6	na				
1	0.0		37.88	na				
0	0.0		48.71	na				
TEST	0.0		48.71	na				

The maximum velocity is 10.47 and it occurs in the pipe between nodes 1 and 0

Final Calculations - Hazen-Williams

FREEDOM FIRE PROTECTION INC.  
171 & 169 NEAL STREET HC2

Page 5  
Date 12/17/12

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftnng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
204 to 20	29.49	1.61 120	3E 12.0 1T 8.0	20.000 20.000	10.340 0.0				
	29.49	0.0332	0.0	40.000	1.326		Vel =	4.65	
	0.0								
	29.49				11.666		K Factor =	8.63	
204 to 203	-15.34	1.61 120	1E 4.0 1T 8.0	12.000 12.000	10.340 0.0				
	-15.34	-0.0099	0.0	24.000	-0.238		Vel =	2.42	
203 to 202	13.98	1.61 120	1E 4.0 1T 8.0	9.830 12.000	10.102 0.0				
	-1.36	-0.0001	0.0	21.830	-0.002		Vel =	0.21	
202 to 201	13.98	1.61 120	2E 8.0 1T 8.0	10.660 16.000	10.100 0.0				
	12.62	0.0069	0.0	26.660	0.184		Vel =	1.99	
201 to 20	14.11	1.61 120	6E 24.0 0.0	26.000 24.000	10.284 0.0				
	26.73	0.0276	0.0	50.000	1.382		Vel =	4.21	
20 to 7	29.50	1.61 120	1T 8.0 0.0	1.500 8.000	11.666 0.0				
	56.23	0.1093	0.0	9.500	1.038		Vel =	8.86	
7 to 6	0.0	1.61 120	1E 4.0 0.0	10.083 4.000	12.704 4.803				
	56.23	0.1094	0.0	14.083	1.541		Vel =	8.86	
6 to 5	0.0	1.61 120	1E 4.0 0.0	2.830 4.000	19.048 0.0				
	56.23	0.1092	0.0	6.830	0.746		Vel =	8.86	
5 to 4	0.0	1.61 120	1E 4.0 0.0	10.500 4.000	19.794 4.545				
	56.23	0.1094	0.0	14.500	1.586		Vel =	8.86	
4 to 3	0.0	1.61 120	1T 8.0 0.0	10.416 8.000	25.925 0.0				
	56.23	0.1094	0.0	18.416	2.014		Vel =	8.86	
3 to 2	0.0	1.61 120	1T 8.0 0.0	7.166 8.000	27.939 0.0				
	56.23	0.1093	0.0	15.166	1.658		Vel =	8.86	
2 to 1	0.0	1.61 120	1Zaa 0.0 0.0	6.166 0.0	29.597 7.612				
	56.23	0.1093	0.0	6.166	0.674		* Fixed loss =	4.942	
							Vel =	8.86	
1 to 0	0.0	1.481 140	0.0 0.0	31.000 0.0	37.883 7.000				
	56.23	0.1235	0.0	31.000	3.828		* Fixed loss =	7	
							Vel =	10.47	
0 to TEST	0.0	12.34 140	1T 93.767 0.0	150.000 93.767	48.711 0.0				
	56.23	0.0	0.0	243.767	0.001		Vel =	0.15	

Final Calculations - Standard

FREEDOM FIRE PROTECTION INC.  
 171 & 169 NEAL STREET HC2

Page 6  
 Date 12/17/12

Hyd. Ref. Point	Qa  Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 56.23				48.712			K Factor = 8.06	