DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

CARLETON STREET APARTMENTS LLC

Located at

84 CARLETON ST

PERMIT ID: 2016-02019

ISSUE DATE: 09/07/2016

CBL: 054 G011001

has permission to For the installation of a Fire Alarm System (Tyco SimplexGrinnell) for the "Carleton Street Apartments LLC".

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Michael White

/s/ Tammy Munson

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

Building Inspections

Fire Department

29 dwelling units

PERMIT ID: 2016-02019 **Located at:** 84 CARLETON ST **CBL:** 054 G011001

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the City of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that are attached to this permit! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases 6 months.
- If the inspection requirements are not followed as stated below, additional fees may be incurred due to the issuance of a "Stop W Order" and subsequent release to continue.

REQUIRED INSPECTIONS:

Electrical - Commercial

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

Permit No: Date Applied For: CBL: City of Portland, Maine - Building or Use Permit 08/01/2016 2016-02019 054 G011001 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716 Proposed Use: Proposed Project Description: Same: Multi-Family ("Carleton Street Apartments LLC") For the installation of a Fire Alarm System (Tyco SimplexGrinnell) for the "Carleton Street Apartments LLC". Reviewer: Robert Wiener **Dept:** Historic Status: Approved w/Conditions **Approval Date:** 09/07/2016 Ok to Issue: Note: **Conditions:** 1) If any changes are made to equipment that must be mounted on the exterior of the building, the revision must be reviewed and approved by Historic Preservation staff prior to installation. 09/07/2016 **Dept:** Zoning Status: Approved **Reviewer:** Christina Stacey **Approval Date:** Ok to Issue: Note: **Conditions:**

Conditions:

Dept: Fire

Note:

1) The fire alarm system shall have a new fire alarm inspection sticker.

Status: Approved w/Conditions

2) The fire alarm technician shall be present for the fire inspection. System acceptance and commissioning must be coordinated with alarm and suppression system contractors and the Fire Department. Call 874-8400 to schedule.

Reviewer: Michael White

09/02/2016

Ok to Issue:

Approval Date:

- 3) All smoke alarms shall be photoelectric.
- 4) The Fire Alarm installation shall comply with the following: City of Portland Chapter 10, Fire Prevention and Protection; NFPA 1, Fire Code (2009 edition), as amended by City Code; NFPA 101, Life Safety Code (2009 edition), as amended by City Code; City of Portland Fire Department Rules and Regulations; NFPA 72, National Fire Alarm and Signaling Code (2010 edition), as amended by Fire Department Rules and Regulations; and NFPA 70, National Electrical Code (2011 edition) as amended by the State of Maine.
- 5) A Knox Box is required.
- 6) All means of egress to remain accessible at all times.
- 7) All construction shall comply with 2009 NFPA 101, Chapter 30 New Apartment Buildings.
- 8) All construction shall comply with 2009 NFPA 1, Fire Code. Review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code (Chapter 1.14.4).
- 9) All construction shall comply with City Code, Chapter 10.

PERMIT ID: 2016-02019 **Located at:** 84 CARLETON ST **CBL:** 054 G011001