

Buildg Rehab 1/8/98

PORTLAND FIRE DEPARTMENT

Portland, Me. 9/20/96

NOTICE OF HAZARDOUS OR DANGEROUS CONDITIONS

Mr. Burnham Realitors
Ms Coastal management co.
P.O. Box 1034 Portland, Me. 04104

127-57 Nothing Done
AGAIN check w/ LT. McDougal

as owner, occupant, agent of premises at 84 CARLTON ST.
you are hereby notified to remedy the following hazardous or dangerous condition now existing, namely:

- ① NO domestic sprinkler head over boiler for fire protection OR fix breaches in fire rated ceilings AND walls.
 - ② outdated fire extinguisher on 3rd floor
 - ③ NO fire rated egress doors on apts leading to common hallways.
- * CALL LT. McDOUGAL @ Fire Prevention to work out replacement plan.

Inspection of building and premises by the authority of Section 1.4 of the Fire Prevention Code.

By order of,

Chief of Department

Recommended time of compliance: contact LT. McDOUGAL (Fire Prevention)

By FF Timothy F. Kane Inspector Badge # 102

Station Bran Hall Company No. Ladder 6