



**. . . Fire Protection by Computer Design**

SPRINKLER SYSTEMS INC.  
P. O. BOX 1285  
2-4 AVON STREET  
LEWISTON, ME 04243  
207-782-0104

Job Name : 17 CARLETON STREET  
Building :  
Location : 17 CARLETON STREET, PORTLAND, MAINE 04101  
System : 1 OF 1  
Contract : 16-149  
Data File : 1614917CARLETONSTREETA1.WXF

HYDRAULIC DESIGN INFORMATION SHEET

Name - 17 CARLETON STREET Date - 3-30-2017  
Location - 17 CARLETON STREET, PORTLAND, MAINE 04101  
Building - System No. - 1 OF 1  
Contractor - BENCHMARK Contract No. - 16-149  
Calculated By - SCOTT E. GARLAND Drawing No. - 1-3 OF 3  
Construction: (X) Combustible ( ) Non-Combustible Ceiling Height VARIES  
OCCUPANCY - RESIDENTIAL - APARTMENTS

S Type of Calculation: ( )NFPA 13 Residential (X)NFPA 13R ( )NFPA 13D  
Y Number of Sprinklers Flowing: ( )1 ( )2 (X)4 ( )  
S ( )Other  
T ( )Specific Ruling Made by Date  
E  
M Listed Flow at Start Point - 17.0 Gpm System Type  
Listed Pres. at Start Point - 12.0 Psi (X) Wet ( ) Dry  
D MAXIMUM LISTED SPACING 18 x 18 ( ) Deluge ( ) PreAction  
E Domestic Flow Added - Gpm Sprinkler or Nozzle  
S Additional Flow Added - Gpm Make RELIABLE Model RFC49  
I Elevation at Highest Outlet - 139.5Feet Size 1/2" X 1/2" K-Factor 4.9  
G Note: Temperature Rating 155 DEG  
N DESIGN AREA #1 - FOURTH FLOOR APARTMENT

Calculation Gpm Required 66.136 Psi Required 46.155 AT BASE OF RISER  
Summary C-Factor Used: Overhead 150 Underground 140

W Water Flow Test: Pump Data: Tank or Reservoir:  
A Date of Test - 4-28-2015 Rated Cap. Cap.  
T Time of Test - @ Psi Elev.  
E Static (Psi) - 50 Elev.  
R Residual (Psi) - 47 Other Well  
Flow (Gpm) - 1034 Proof Flow Gpm  
S Elevation - 98.0

P Location: ON EMERY STREET AT PINE STREET, APPROX. 650' FROM THE BLDG

P  
L Source of Information: PORTLAND WATER DISTRICT  
Y

# Fittings Used Summary

SPRINKLER SYSTEMS INC.  
17 CARLETON STREET

Page 3  
Date 3-30-2017

## Fitting Legend

Abbrev.	Name	½	¾	1	1¼	1½	2	2½	3	3½	4	5	6	8	10	12	14	16	18	20	24	
Bvca	B Fly Vic 705						6	6	7		8	12	14	16	18	19						
E	NFPA 13 90' Standard Elbow	1	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61	
F	NFPA 13 45' Elbow	1	1	1	1	2	2	3	3	3	4	5	7	9	11	13	17	19	21	24	28	
Fsp	Flow Switch Potter VSR	Fitting generates a Fixed Loss Based on Flow																				
G	NFPA 13 Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13	
S	NFPA 13 Swing Check	0	0	5	7	9	11	14	16	19	22	27	32	45	55	65						
T	NFPA 13 90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121	
Zac	Ames 2000SS	Fitting generates a Fixed Loss Based on Flow																				

## Unit Summary

Diameter Units           Inches  
Length Units               Feet  
Flow Units                 US Gallons per Minute  
Pressure Units             Pounds per Square Inch

Note: Fitting Legend provides equivalent pipe lengths for fittings types of various diameters. Equivalent lengths shown are standard for actual diameters of Sched 40 pipe and CFactors of 120 except as noted with \*. The fittings marked with a \* show equivalent lengths values supplied by manufacturers based on specific pipe diameters and CFactors and they require no adjustment. All values for fittings not marked with a \* will be adjusted in the calculation for CFactors of other than 120 and diameters other than Sched 40 per NFPA.

**SUPPLY ANALYSIS**

<b>Node at Source</b>	<b>Static Pressure</b>	<b>Residual Pressure</b>	<b>Flow</b>	<b>Available Pressure</b>	<b>Total Demand</b>	<b>Required Pressure</b>
TEST	50.0	47	1034.0	49.981	66.14	43.578

**NODE ANALYSIS**

<b>Node Tag</b>	<b>Elevation</b>	<b>Node Type</b>	<b>Pressure at Node</b>	<b>Discharge at Node</b>	<b>Notes</b>
TYP	0.0	4.9	7.04	13.0	
TYP1	0.0	4.9	12.04	17.0	
1	139.5	4.8	11.92	16.56	K=K @ DROP
2	139.5	4.8	12.54	17.0	K=K @ DRP1
3	139.5	4.8	11.21	16.05	K=K @ DROP
4	139.5	4.8	11.87	16.52	K=K @ DROP
A	139.5		13.94		
B	139.5		14.69		
C	139.5		15.17		
D	139.5		15.34		
E	139.5		15.65		
FT	139.0		19.19		
G	130.5		22.89		
H	120.0		27.45		
J	110.25		31.68		
T	98.833		36.68		
RT	98.833		36.75		
TOV	95.833		41.06		
RB	91.833		46.15		
X1	91.833		46.17		
X2	91.833		46.22		
X3	91.833		46.23		
TEST	98.0		43.58		

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
TYP to DROP	0 0	4.90	13.00 13.0	1 1.101	T 0.0 0.0	9.563 0.0 10.062	150 0.0306	7.039 0.0 0.308		Vel = 4.38	
DROP			0.0 13.00					7.347		K Factor = 4.80	
TYP1 to DRP1	0 0	4.90	17.00 17.0	1 1.101	T 0.0 0.0	9.563 0.0 10.062	150 0.0504	12.037 0.0 0.507		Vel = 5.73	
DRP1			0.0 17.00					12.544		K Factor = 4.80	
1 to 2	139.500 139.500	4.8	16.56 16.56	1 1.101	E 0.0 0.0	3.825 0.0 12.992	150 0.0480	11.920 0.0 0.624		K = K @ DROP Vel = 5.58	
2 to A	139.500 139.500	4.8	17.00 33.56	1.25 1.394	E 0.0 0.0	4.762 0.0 24.886	150 0.0562	12.544 0.0 1.398		K = K @ DRP1 Vel = 7.05	
A			0.0 33.56					13.942		K Factor = 8.99	
3 to 4	139.500 139.500	4.8	16.06 16.06	1 1.101	E 0.0 0.0	3.825 0.0 14.617	150 0.0454	11.206 0.0 0.663		K = K @ DROP Vel = 5.41	
4 to A	139.500 139.500	4.8	16.52 32.58	1 1.101	T 0.0 0.0	9.563 0.0 12.354	150 0.1678	11.869 0.0 2.073		K = K @ DROP Vel = 10.98	
A			0.0 32.58					13.942		K Factor = 8.73	
A to B	139.500 139.500		66.14 66.14	1.5 1.598		0.0 0.0 7.417	150 0.1013	13.942 0.0 0.751		Vel = 10.58	
B to C	139.500 139.500		0.0 66.14	2 2.003	T 0.0 0.0	12.965 0.0 14.215	150 0.0337	14.693 0.0 0.479		Vel = 6.73	
C to D	139.500 139.500		0.0 66.14	3 3.26		0.0 0.0 34.292	120 0.0048	15.172 0.0 0.164		Vel = 2.54	
D to E	139.500 139.500		0.0 66.14	3 3.26	T 0.0 0.0	20.159 0.0 67.159	120 0.0047	15.336 0.0 0.319		Vel = 2.54	
E to FT	139.500 139		0.0 66.14	3 3.26	Bvca 3E S Fsp 0.0	9.408 28.223 21.503 0.0	120 0.0047	15.655 3.217 0.321		* Fixed Loss = 3 Vel = 2.54	
FT to G	139 130.500		0.0 66.14	4 4.26		0.0 0.0 8.500	120 0.0014	19.193 3.681 0.012		Vel = 1.49	
G to H	130.500 120		0.0 66.14	4 4.26		0.0 0.0 10.500	120 0.0012	22.886 4.548 0.013		Vel = 1.49	

# Final Calculations - Hazen-Williams

SPRINKLER SYSTEMS INC.  
17 CARLETON STREET

Page 6  
Date 3-30-2017

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqv. Ln.	Pipe Ftng's Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
H to J	120 110.250		0.0 66.14	4 4.26		0.0 0.0 9.750	120	27.447 4.223			Vel = 1.49
J to T	110.250 98.833		0.0 66.14	4 4.26	T 26.334 0.0	11.417 26.334 37.751	120	31.682 4.945			Vel = 1.49
T to RT	98.833 98.833		0.0 66.14	4 4.26	Bvca 2E 26.334	10.534 26.334 36.868	120	36.676 0.0			Vel = 1.49
RT to TOV	98.833 95.833		0.0 66.14	4 4.26	Fsp 0.0	3.000 0.0	120	36.754 4.299		* Fixed Loss = 3	Vel = 1.49
TOV to RB	95.833 91.833		0.0 66.14	4 4.26	Zac 0.0	4.000 0.0	120	41.057 5.092		* Fixed Loss = 3.36	Vel = 1.49
RB to X1	91.833 91.833		0.0 66.14	6 6.16	E G T 43.037	20.084 4.304 43.037 107.425	140	46.155 0.0			Vel = 0.71
X1 to X2	91.833 91.833		0.0 66.14	6 6.16	T 0.0	43.037 43.037 268.037	140	46.172 0.0			Vel = 0.71
X2 to X3	91.833 91.833		0.0 66.14	8 8.27	2F 0.0	28.468 28.468 388.468	140	46.215 0.0			Vel = 0.40
X3 to TEST	91.833 98		0.0 66.14	6 6.16	F T 43.037	10.042 43.037 53.079 118.079	140	46.230 -2.671			Vel = 0.71
TEST			0.0 66.14					43.578			K Factor = 10.02

# Water Supply Curve C

SPRINKLER SYSTEMS INC.  
17 CARLETON STREET

Page 7  
Date 3-30-2017

City Water Supply:  
C1 - Static Pressure : 50  
C2 - Residual Pressure: 47  
C2 - Residual Flow : 1034

Demand:  
D1 - Elevation : 17.974  
D2 - System Flow : 66.136  
D2 - System Pressure : 43.578  
Hose ( Demand ) : \_\_\_\_\_  
D3 - System Demand : 66.136  
Safety Margin : 6.403

