



STAIR DOWN TO EXTERIOR EXIT ONLY
 DOOR TO BASEMENT AT 1ST FLOOR TO BE REMOVED AND INFILL w/ 1 HR PARTITION; (AS PER FIRE DEPT REVIEW.)

EXISTING BATHROOM - new tile/finishes only

EXISTING BATHROOM - new tile/finishes only

STAIR DOWN TO EXTERIOR EXIT.

* REPLACE DOOR TO ATTIC w/ 1 HR STEEL DOOR w/ DEAD BOLT - NO ACCESS - AS (PER FIRE DEPT REVIEW)

UNIT 4
1,036 SF
 UNIT 3
791 SF

* WALL TYPES ① ② ③ ON SHEET A3.2

* WINDOW SIZES ON LB 2.2

WEST-SECOND FLOOR
 1/8" = 1'-0"
 0 2 4

A 2.2 PROPOSED PLAN