

**From:** "Dennis "Chip" Martin" <dmartin7@maine.rr.com>  
**To:** "Benjamin Wallace" <wallaceb@portlandmaine.gov>  
**Date:** 9/2/2009 5:51:17 AM  
**Subject:** Re: 240 Brackett Street

This work has been completed. A 90 minute, special order fire door was installed on 8/28/09.-Dennis Martin

----- Original Message -----

From: "Benjamin Wallace" <wallaceb@portlandmaine.gov>  
To: <dmartin7@maine.rr.com>  
Cc: "Daniel Dyer" <DSD@portlandmaine.gov>  
Sent: Tuesday, June 23, 2009 8:40 AM  
Subject: 240 Brackett Street

> Good morning,  
> Thank you for contacting me this morning regarding the fire door for  
> the first floor. I will grant an extension until August 31st to install  
> the 60-minute fire door assembly as it is a custom size and shape.  
> Please reply to this e-mail with your affirmation and contact  
> information.  
> Thanks,  
>  
> Benjamin A. Wallace Jr.  
> Fire Prevention Officer  
> Portland Fire Department  
> 380 Congress Street  
> Portland, Maine 04101  
> (207)756-8096  
> wallaceb@portlandmaine.gov  
>