- hand railing 36" Ht
- Return hand rail ends to wall
- Finished stairwell width greater than 36"

Stair Elevation Drawing

Date: 06/10/14

Reviewed for Code Compliance
Inspection Division
Approved with Conditions

CITY OF PORTLAND, MAINE