
59 Pine St smoke detector

3 messages

Michael Clinton <mclinton@portlandmaine.gov>
To: alarmman@roadrunner.com

Tue, May 28, 2019 at 12:36 PM

Hello,
Portland Fire Department authorizes, at 59 Pine St, Portland, ME, the replacement of the smoke detector in the kitchen over to a heat detector due to several false alarm calls. This authorization is only for this single device in the kitchen.

Please feel free to call with any questions.

--
Thanks,
Mike Clinton
Fire Alarm Technician
Portland Fire Dept - Fire Prevention
mclinton@portlandmaine.gov
207-653-2450

Eric Falconer <alarmman@roadrunner.com>
To: Michael Clinton <mclinton@portlandmaine.gov>

Tue, May 28, 2019 at 1:09 PM

Mike,

Can you please reword the description of the existing smoke detector to be switched to a heat detector to read 1st floor Front Hall Entry Smoke Detector. Please re-email me this information. This is the smoke detector that has been causing the kitchen smoke issues. Please feel free to call me at 207-985-3338.

Thank you
Eric Falconer

[Quoted text hidden]

[Quoted text hidden]

Notice: Under Maine law, documents - including e-mails - in the possession of public officials or city employees about government business may be classified as public records. There are very few exceptions. As a result, please be advised that what is written in an e-mail could be released to the public and/or the media if requested.

Michael Clinton <mclinton@portlandmaine.gov>
To: Eric Falconer <alarmman@roadrunner.com>

Tue, May 28, 2019 at 3:55 PM

Hi Eric,
Portland Fire Department authorizes, at 59 Pine St, Portland, ME, the replacement of the 1st floor Front Hall Entry smoke detector over to a heat detector due to several false alarm calls. This authorization is only for this single device at this address.

Thanks,
Mike Clinton
[Quoted text hidden]