

- 2/6/02 met on site. Need Handrail on Rear Steps, Close-Risers  
went through entire Building w/ owner. O.K. to Close in JRM
- 2/11/02 Sent FAN Dunn requirements for Fire Rating (1 hr)  
and sound transmission. Once he chooses an assembly  
I advised to submit the method for the record. JB
- 3/28/02 Final inspection. Tempered glass has been installed. OK.  
For c/o JRM



CITY OF PORTLAND, MAINE  
Department of Building Inspection

# Certificate of Occupancy

LOCATION 77 Carleton St CBL 055 C003001

Issued to Abilities & Goodwill Inc/no contractor/self Date of Issue 03/28/2002

**This is to certify** that the building, premises, or part thereof, at the above location, built — altered — changed as to use under Building Permit No. 01-1223, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES  
2 Family Dwelling

APPROVED OCCUPANCY  
Use Group R3 Type 5b  
(Boca 1999)

**Limiting Conditions:** This is a certificate to change the approved use from a one family to a two family. Any future construction will require separate permits and approvals

This certificate supersedes certificate issued

Approved:

3/28/02  
(Date)

*Jon Reed*  
Inspector

*[Signature]*  
Inspector of Buildings

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

JK