

7/16/02 Insp. 3 Sono Tube Footings 48" within existing  
foot print. Ledger boards Lagged to house - joist hangers  
fastened. OK to pour. 2x8's PT Framing replaced  
2x12 as on plans ok - 2x8 spans max 12'3" - deck  
is 7'3" and Bearing post spans 5'2" on  
double 2x8 Beam JB

9/18/02 Completed.  
AN

055-C-013

020048