

Fire Alarm System Record of Completion

Name of protected property: 628 walker st portland, ME

Address: _____

Rep. of protected property (name/phone): _____

Authority having jurisdiction: Portland Fire Department

Address/telephone number: _____

Organization name/phone _____ Representative name/phone _____
 Installer Protection Professionals

Supplier Fariday

Service organization _____

Location of record (as-built) drawings Pro Pro

Location of owners manuals: Pro Pro

Location of test reports: Pro Pro

A contract, dated _____, for test and inspection in accordance with NFPA standard(s)

Contract No(s). _____ Effective date: _____ Expiration date: _____

System Software

(a) Operating System Software Revision Level(s): 6.1.5

(b) Application Software Revision Level(s): 6.01

(c) Revision Completed by: _____

(name)

(firm)

1. Type(s) of System or Service

_____ NFPA 72, Chapter 6 - Local

If alarm is transmitted to location(s) off premises, list where received: _____

_____ NFPA 72, Chapter 8 Remote Station

Telephone numbers of the organization receiving alarm:

Alarm: _____

Supervisory: _____

Trouble: _____

If alarms are retransmitted to public fire service communications center or others, indicate location and telephone number of the organization receiving alarm: _____

_____ NFPA 72, Chapter 8 Proprietary

Telephone numbers of the organization receiving alarm:

Alarm: _____

Supervisory: _____

Trouble: _____

If alarms are retransmitted to public fire service communications center or others, indicate location and telephone number of the organization receiving alarm: _____

Indicate how alarm is retransmitted: _____



NFPA 72, Chapter 8 Central Station

Prime contractor: Rapid Response

Central station location: _____

Means of transmission of signals from the protected premises to the central station:

☐ McCulloch ☐ Multiplex ☐ One-way radio
☒ Digital alarm communicator ☐ Two-way radio ☐ Others

Means of transmission of alarms to the public fire service communications center:

(a) _____

(b) _____

System Location: _____

NFPA 72, Chapter 9 - Auxiliary

Indicate type of connection: ☐ Local energy ☐ Shunt ☐ Parallel telephone

Location of telephone number for receipt of signals: _____

2. Record of System Installation

(Fill out after installation is complete and wiring checked for opens, shorts, ground faults, and improper branching, but prior conducting operational acceptance tests.)

This system has been installed in accordance with the NFPA standards as shown below, was inspected by BYRON DAULS on 10/19/06, includes the devices shown in 5 and 6, and has been in service since 10/16/06.

☒ NFPA 72, Chapters 1 2 3 4 5 6 7 8 9 10 11 (circle all that apply)

☐ NFPA 70, *National Electrical Code*, Article 760

☐ Manufacturer's Instructions

☐ Other (specify): _____

Signed: Byron D. Date: _____

Organization: Pro Pro

3. Record of System Operation

Documentation in accordance with Inspection Testing Form, Figure 10.6.2.3, is attached _____

All operational features and functions of this system were tested by BYRON DAULS on 10/19/06, and found to be operating properly in accordance with the requirements of:

☒ NFPA 72, Chapters 1 2 3 4 5 6 7 8 9 10 11 (circle all that apply)

☒ NFPA 70, *National Electrical Code*, Article 760

☒ Manufacturer's Instructions

☐ Other (specify): _____

Signed: Byron D. Date: _____

Organization: Pro Pro

4. Signaling Line Circuits

Quantity and class of signaling line circuits connected to system (see NFPA 72, Table 6.6.1):

Quantity: 2 Style: _____ Class: B

5. Alarm-Initiating Devices and Circuits

Quantity and class of initiating device circuits (see NFPA 72, Table 6.5)

Quantity: 1 Style: _____ Class: B

MANUAL

(a) Manual stations Noncoded 8 Transmitters _____ Coded _____ Addressable _____

(b) Combination manual fire alarm and guard's tour coded stations _____

AUTOMATIC

Coverage: Complete: _____ Partial: _____

Selective: _____ Nonrequired: _____

(a) Smoke detectors Ion _____ Photo _____ Addressable 10

(b) Duct detectors Ion _____ Photo _____ Addressable _____

(c) Heat detectors FT _____ RR _____ FT/RR _____ RC _____ Addressable _____

(d) Sprinkler waterflow indicators: Transmitters _____ Noncoded _____ Coded _____ Addressable _____

(e) The alarm verification feature is disabled _____ or enabled _____, changed from _____ seconds to _____ seconds.

(f) Other (list): _____

6. Supervisory Signal-Initiating Devices and Circuits (use blanks to indicate quantity of devices)

GUARD'S TOUR

(a) _____ Coded Stations

(b) _____ Noncoded Stations

(c) _____ Compulsory guard tour system comprised of _____ transmitter stations & intermediate stations

NOTE: Combination devices recorded under 5(b), Manual, and 6(a), Guard Tour.

SPRINKLER SYSTEM

(a) _____ Valve supervisory switches

(b) _____ Building temperature points

(c) _____ Site water temperature points

(d) _____ Site water supply level points

Electric fire pump:

(e) _____ Fire pump power

(f) _____ Fire pump running

(g) _____ Phase reversal

Engine-driven fire pump:

(h) _____ Selector in auto position

(i) _____ Engine or control panel trouble

(j) _____ Fire pump running

Engine-driven generator:

(k) _____ Selector in auto position

(l) _____ Control panel trouble

(m) _____ Transfer switches

(n) _____ Engine running

Other supervisory function(s) (specify): _____

7. Annunciator(s)

Number: 1 Type: ROC-2 Location: 6 walker St 1st Floor Lobby

8. Alarm Notification Appliances and Circuits

NFPA 72, Chapter 6 - Emergency Voice/Alarm Service

Quantity of voice/alarm channels: _____ Single: _____ Multiple: _____

Quantity of speakers installed: _____ Quantity of speaker zones: _____

Quantity of telephones or telephone jacks included in system: _____

Quantity and class of notification appliance circuits connected to system (see NFPA 72, Table 6.7)

Quantity: _____ Style: _____ Class: _____

Types and quantities of notification appliances installed:

(a) Bells _____ With Visible _____

(b) Speakers _____ With Visible _____

(c) Horns 10 _____ With Visible 10 _____

(d) Chimes _____ With Visible _____

(e) Other: _____ With Visible _____

(f) Visual appliance without audible: _____

9. System Power Supplies

(a) Fire Alarm Control Unit: Nominal voltage: 120 Current rating: _____
Overcurrent protection: Type: Breaker Current rating: 20 Location: Main Panel Basement 8 Walker

(b) Secondary (standby):

Storage battery: 2 12 V Amp-hour rating 7 AH

Calculated capacity to drive system, in hours: 24

Engine-driven generator dedicated to fire alarm system: _____

Location of fuel storage: _____

(c) Emergency system used as backup to primary power supply: _____

Emergency system described in NFPA 70, Article 700: _____

10. Comments:

Frequency of routine tests and inspections, if other than in accordance with the referenced NFPA Standard(s): _____

System deviations from the referenced NFPA standard(s) are: _____

(signed) for installation contractor/supplier

(title)

(date)

Byron D

Tech

10/12/06

(signed) for alarm service company

(title)

(date)

(signed) for central station

(title)

(date)

Upon completion of the system(s) satisfactory test(s) witnessed (if required by the Authority Having Jurisdiction): _____

(signed) Representative of the Authority Having Jurisdiction

(title)

(date)

Reprinted with permission from NFPA 72, *National Fire Alarm Code*, Copyright® 2002, National Fire Protection Association, Quincy, MA 02269. This reprinted material is not the complete and official position of the NFPA on the referenced subject which is represented only by the standard in its entirety.