



## City of Portland Inspection Violations

<b>Case Number:</b>	LTR1800656	<b>Case Module:</b>	Permit Management
<b>Inspection Date:</b>	08/09/2018	<b>Inspection Status:</b>	In Violation
<b>Inspector:</b>	Ladder 36	<b>Inspection Type:</b>	Long Term Rental Registration
<b>Job Address:</b>	17 Dow St Portland, ME	<b>Parcel Number:</b>	055 D011001

<b>Contact Type</b>	<b>Company Name</b>	<b>Name</b>
Owner	17-19 Dow Street LLC	C/O Cathy-Ann Wirth

Checklist Item	Passed	Comments
General Comments	False	

### Noncompliance

Code Name	Comments	Deadline
NFPA 101-31.2.2.1 Fire Doors Required (1-3 doors required) 1-hour fire rated doors and assemblies required, including self-closing and self-latching mechanisms.	Both basement doors.	12/31/2018