


CITY OF PORTLAND
 FIRE PREVENTION BUREAU
 380 Congress Street, Portland, Maine 04101
 fireprevention@portlandmaine.gov
 (207) 874-8400



NOTICE OF VIOLATION AND ORDER TO CORRECT

August 8, 2017

CARRIE PEOPLES
 26 DOW ST
 PORTLAND ME 04102

Location 26 DOW ST	CBL 055 E004001	Inspection Date 7/22/2017
Inspector Jonathan Hendricks	Inspection Type FP Re-Inspection	Status Failed

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must propose a date of completion to remedy each violation, a final date of completion, and a date of re-inspection.

You must send this form to the Fire Prevention Bureau no later than 8/30/2017.

Your failure to submit a plan of action by the date provided, or to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

Violation	Proposed Date of Completion
NFPA 101- 31.3.1.1.1 VERTICAL OPENINGS NOT FIRE RATED; Vertical openings shall be enclosed or protected in accordance with Section 8.6. Rear stair well is exposed studs, not fire rated.	<u>11/01/17</u>
NFPA 101- 7.2.1.8.1 FIRE DOORS MUST BE SELF- OR AUTO-CLOSING; A door leaf normally required to be kept closed shall not be secured in the open position at any time and shall be self-closing or automatic-closing in accordance with 7.2.1.8.2, unless otherwise permitted by 7.2.1.8.3. Assure self-closing hinges on all unit doors.	<u>09/10/17</u>
NFPA 101- 7.2.8.5.1 HANDRAILS REQUIRED ON STAIRS; All fire escape stairs shall have walls or guards and handrails on both sides in accordance with 7.2.8.4.1 (b). Porch needs railing. Problem correction was not adequate	<u>10/01/17</u>
FINAL DATE OF COMPLETED VIOLATION(S)	<u>11/04/17</u>
FIRE PREVENTION BUREAU RE-INSPECTION OF COMPLETED VIOLATION(S)	<u>11/04/17</u>

The Bureau reserves the right to reject or modify any proposed plan of action, and may require evidence of sufficient financial and technical capacity to complete the proposed plan. Please contact the Bureau with any questions.

VIOLATOR CERTIFICATION

I agree to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau prior to the deadline to request an extension, which is entirely within the Bureau's discretion to grant or deny.

I further understand that it is my responsibility to schedule a reinspection of my property once the violations have been remedied to do so. My failure to schedule a reinspection shall be deemed an admission that the violations have not been remedied.

If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.

8/31/2017
Date

[Signature]
Responsible Party

Date

Responsible Party

SEEN AND AGREED

8/31/17
Date

CAPT. [Signature]
Fire Prevention Bureau



Maine Medical Center

MaineHealth

P2c Maine Medical Center

22 Bramhall Street

Portland ME 04102

Phone: 207-662-1919

Fax: 207-662-3848

Date: 8.31-17

To: Fire Prevention

Fax: 207-874-8410

Pages with cover: 3

Regarding: Inspection

The patient information contained in this fax is confidential. This message is intended only for the individual or entity it is addressed and exempt from disclosure under Applicable Law.