

CITY OF PORTLAND
 FIRE PREVENTION BUREAU
 780 Congress Street, Portland, Maine 04101
 fireprevention@portlandmaine.gov
 (207) 878-8400

NOTICE OF VIOLATION AND ORDER TO CORRECT

March 16, 2018

CARRIE PERSPIER
 26 THOMAS ST
 PORTLAND ME 04102

Location 26 THOMAS ST	Call 053 1-255-1000	Inspection Date 3/16/2018
Inspector John Brennan	Inspection Type FP Routine Inspection	Status Failed

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must propose a date of completion to remedy each violation, a final date of completion, and a date of re-inspection.

You must send this form to the Fire Prevention Bureau no later than 4/15/2018.

Your failure to submit a plan of action by the date provided, or to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

Violation	Proposed Date of Completion
NFPA 101-7.2.4.3.1 FIRE BARRIER REQUIRES MAINTENANCE: Fire barriers separating buildings or areas between which there are horizontal exits shall have a minimum 2-hour fire resistance rating, unless otherwise provided in 7.2.4.4.1, and shall provide a separation that is continuous to the finished ground level. The extra door and the rear stairwell for the second floor apartment must be a 1-hr rated enclosure using 2 layers of fire rated sheetrock where the door once was or you can install a 60 minute rated self closing fire door instead.	06 / 09 / 18
NFPA 101- 8.3.4.2 60 MINUTE FIRE DOOR REQUIRED: Refer to NFPA 101- Table 8.3.4.2 that states fire door assemblies for vertical shafts (including stairways, shafts, and refuse chutes) are rated and required for 1 hour. Both apartment doors in the rear stairwell must be 60 minute rated fire doors with self-closing hardware. Also, once the doors are in, please label them with their apartment number.	06 / 09 / 18
FINAL DATE OF COMPLETED VIOLATION(S)	06 / 09 / 18
FIRE PREVENTION BUREAU RE-INSPECTION OF COMPLETED VIOLATION(S)	06 / 11 / 18

The Bureau reserves the right to reject or modify any proposed plan of action, and may require evidence of sufficient financial and technical capacity to complete the proposed plan. Please contact the Bureau with any questions.

VIOLATOR CERTIFICATION

I agree to remedy the violations listed within the timeframe provided. If I require additional time as example, I understand that I must contact the Fire Prevention Bureau prior to the deadline to request an extension, which is entirely within the Bureau's discretion to grant or deny.

I further understand that it is my responsibility to schedule a reinspection of my property once the violations have been remedied to do so. My failure to schedule a reinspection shall be deemed an admission that the violations have not been remedied.

If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4432 and may be subject to further legal action.

Sunday
04-25-2018
Date

Adam Puffer
Responsible Party

Date

Responsible Party

SEEN AND AGREED

4/25/18
Date

Chris [Signature]
Fire Prevention Bureau