

Portland, Maine

Yes. Life's good here.

Portland Fire Department
Fire Prevention Bureau
380 Congress St
Portland, ME 04101

June 20, 2016

Dear Mr. Power,

This letter is to confirm we have accepted your Plan of Action for the property located on 22 Dow St. According to the email we received on June 19, 2016, all violations will be in compliance no later than September 30, 2016. If there are any changes to this plan, please contact us at 207-874-8400.

Sincerely,



OFFICE USE ONLY

6/19/16

Date Submitted

9/30/16

POA Completion Date

PETRUCCELLI

Approved By (Print)

6/20/16

Date

Re: Fire Safety Plan for 22--Attached

David Petruccelli <petruccellid@portlandmaine.gov>

Mon, Jun 20, 2016 at 7:33 AM

To: Matt Power <power.matt@yahoo.com>

Cc: Tori Ross <MESERVEV@portlandmaine.gov>

Mr. Power,

This plan is acceptable to the fire department. Please keep in touch with us if you run into any trouble and need any kind of extension.

Thank you,

Capt. Petruccelli

Portland Fire Department
Fire Prevention &
Community Outreach Branch
380 Congress St
Portland, ME 04101

Office: 207-874-8400

Mobile: 207-400-7488

Fax: 208-874-8410

On Sun, Jun 19, 2016 at 5:57 PM, Matt Power <power.matt@yahoo.com> wrote:

Hi Capt. Petruccelli

Here's our plan for correcting the fire issues at 22 Dow Street, along with a timetable.

We will fix the hole in the back hallway ceiling and install the sprinkler above the two gas boilers by July 7th.

We will install the steel fire doors over the summer. There are five total, three in the back stairway, including one for the cellar door, and two in the front stairway. We will have them all installed by the end of September.

I hope this plan works for you. The doors are quite expensive so we are trying to spread out the installations over a few months.

thankyou

Matt Power

207-274-1327

David Petruccelli wrote: