

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND BUILDING PERMIT



This is to certify that  
GINN PORTLAND LLC

Located at  
704 CONGRESS ST

PERMIT ID: 2015-00267      ISSUE DATE: 03/11/2015      CBL: 055 E026001

has permission to **For the installation of a Non-Water-Based Fire Suppression System (Pyro-Chem UL 1254 Gas Island Fire Suppression System in Canopy) for the 7-Eleven Store.**  
provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise cloed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ David Petruccelli

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY  
THERE IS A PENALTY FOR REMOVING THIS CARD**

*Approved Property Use - Zoning*

*Building Inspections*

*Fire Department*

**Classification:**

Class C Mercantile

ENTIRE

BUILDING PERMIT INSPECTION PROCEDURES  
Please call 874-8703 (ONLY)  
or email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)

**Check the Status or Schedule an Inspection On-Line at  
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

## **REQUIRED INSPECTIONS:**

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

<b>City of Portland, Maine - Building or Use Permit</b>		<b>Permit No:</b> 2015-00267	<b>Date Applied For:</b> 02/18/2015	<b>CBL:</b> 055 E026001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
<b>Proposed Use:</b> Same: Retail - 7-Eleven Store		<b>Proposed Project Description:</b> For the installation of a Non-Water-Based Fire Suppression System (Pyro-Chem UL 1254 Gas Island Fire Suppression System in Canopy) for the 7-Eleven Store.		
<b>Dept:</b> Zoning		<b>Status:</b> Approved w/Conditions	<b>Reviewer:</b> Tammy Munson	<b>Approval Date:</b> 03/11/2015
<b>Note:</b>		<b>Ok to Issue:</b> <input checked="" type="checkbox"/>		
<b>Conditions:</b>		1) This approves the installation only. It does not verify the legal use of the property.		
<b>Dept:</b> Fire		<b>Status:</b> Approved w/Conditions	<b>Reviewer:</b> David Petruccelli	<b>Approval Date:</b> 03/11/2015
<b>Note:</b>		<b>Ok to Issue:</b> <input checked="" type="checkbox"/>		
<b>Conditions:</b>		1) Shall have State Fire Marshall Permit. Shall have DEP Permit. 2) Shall meet the requirements the most recent NFPA 30A Code for Motor Fuel Dispensing Facilities and Repair Garages. 3) Shall meet the requirements the most recent NFPA 30 Flammable and Combustible Liquids Code. 4) Construction or installation shall comply with City Code Chapter 10. 5) Street addresses shall be marked on the structure and shall be as approved by the City E-911 Addressing Officer. Contact Michelle Sweeney at 874-8682 for further information. 6) All outstanding code violations shall be corrected prior to final inspection. 7) Any cutting and welding done will require a Hot Work Permit from Fire Department. 8) Shall meet the requirements of 2009 NFPA 1 Fire Code. 9) All construction shall comply with City Code Chapter 10. <a href="http://www.portlandmaine.gov/citycode/chapter010.pdf">http://www.portlandmaine.gov/citycode/chapter010.pdf</a> Shall meet the requirements of 2009 NFPA 1 Fire Code.		