

Portland, Maine



Yes. Life's good here.

Certified Tracking # 7017-2680-0000 - 5498-1372

Permitting and Inspections Department
Michael A. Russell, MS, Director

Timothy Gebhardt
20 Dow Street
Portland, Maine 04102

01/26/2018

Per direction from the Fire Prevention Bureau Division Chief Thompson, your permit 2017-01634 to construct a fence between building numbers 20 and 22 on Dow Street has been denied. The reason for the denial is the proposed fence location will obstruct the exit access between the buildings. You have the right to appeal this decision per City Code 10 section 10-23 within 10 days of this notice.

Jason Grant
Life Safety Code Enforcement Officer
City of Portland
389 Congress Street, Rm. 315
Portland, Maine 04101