

10/16/08

Daniel Dyer  
City of Portland Fire Department  
380 Congress Street  
Portland, Maine 04101

Re: 184 Clark Street #233798-0-0

Dear Daniel,

This is a follow up to the inspection notice that was sent out on 8/26/08 to W-2 Realty Trust.

Completed:

The large holes in the back hallway walls and ceiling on the 3<sup>rd</sup> floor have been repaired. The plaster and lath has been removed, the walls insulated and wall board put up.

Request for Extension:


I would like to request that the fire doors in the back hallways be installed over the next two years. I will do the two doors on the third floor by June 1, 2009 and the two doors on the second floor by June 1<sup>st</sup> of 2010.

I would also like to request an extension to January 1, 2009 to install the remaining smoke detectors needed in the apartments.

With the heating season approaching and the high cost of fuel anticipated, it will be a hardship to have to install the fire doors at this time. I am guessing that it will cost approximately \$500 to install each door. If I am able to do these repairs earlier, I will let you know, as I know it is in the best interest for improving the safety of the building.

Thank you in advance for your consideration. I can be reached at 207-749-7337 or at [Jwweir@maine.rr.com](mailto:Jwweir@maine.rr.com) if you need to discuss this further.

Sincerely,

  
John W. Weir  
W-2 Realty Trust