

CITY OF PORTLAND
 FIRE PREVENTION BUREAU
 380 Congress Street, Portland, Maine 04101
 fireprevention@portlandmaine.gov
 (207) 874-8400

NOTICE OF VIOLATION AND ORDER TO CORRECT

October 18, 2017

Responsible Party 1: ANNALIESE LAFAYETTE 107 EMERY ST # 1 PORTLAND, ME 04102		
Location 107 EMERY ST	CBL 056 D009001	Inspection Date 6/1/2017
Inspector Scott True	Inspection Type FP Routine Inspection	Status Failed

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct by the date listed.

You must contact the Fire Prevention Bureau to lock the keys in the Knox Box system.

Your failure to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

Violation	Proposed Date of Completion
PORTLAND CHAPTER 10 CODE SECTION 12 KNOX BOX REQUIRED; Knox boxes are required for all buildings with fire alarm or suppression systems. https://www.knoxbox.com/	12 / 15 / 2017
FINAL DATE OF COMPLETED VIOLATION(S)	By 12 / 15 / 17
FIRE PREVENTION BUREAU RE-INSPECTION OF COMPLETED VIOLATION(S)	_ / _ / _

VIOLATOR CERTIFICATION

I agree to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau prior to the deadline to request an extension, which is entirely within the Bureau's discretion to grant or deny.

If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.

11/7/2017
Date

Annaliese Lafayette
Responsible Party

Date

Responsible Party

SEEN AND AGREED

11/13/2017
Date

CAPT. JRB [Signature] 17
Fire Prevention Bureau