



Portland Fire Department Monthly School Inspection

Name: <u>Reiche School</u>	Address: <u>166 Brackett St</u>
Principal: <u>Marcia Gendron</u>	Emergency contact #: <u>207-934-8081</u>
Date inspected: <u>3-30-09</u>	Inspector: <u>Capt. Dyer</u>
Time in: <u>535</u>	Time out: _____

Fire Drills Conducted Yes No Date of last drill: 3-16-09 1415 hrs.

EXITS:	Pass	Fail	Notes:
Exit / Escapes clear of obstructions		<input checked="" type="checkbox"/>	<u>Exit doors stick 2nd floor</u> <u>Emergency lights 2nd floor - test</u>
Exit signs & Emer lights properly lit		<input checked="" type="checkbox"/>	

Fire Alarm System
Panel clear, accessible, operational

Fire Extinguishers
Extinguishers full & tagged annually
Extinguishers accessible


Heating System
Boiler room clear of all combustibles
Boiler room properly rated/protected

Electrical system
Extension cord use vs. permanent
Electrical panels clear & accessible
Electrical circuits clearly identified

Sprinkler System
Sprinkler heads >18" of clearance
Sprinkler Rm & FDC labeled & clear
Spare heads & wrench supplied
Sprinkler system tagged insp. date 3-18-09

House Keeping
Furnishings & decorations flame rest
Art work displayed < 20% wall area
Housekeeping organized for safety

Additional Safety Concerns:



Portland Fire Department Monthly School Inspection

Name: Marcia Gendron	Address: 166 Brackett St
Principal:	Emergency contact #:

Date inspected: 5/21/09	Inspector: Lt Robert Eaton #54
Time in: 0930	Time out: 10:15

Fire Drills Conducted Yes No Date of last drill: _____

EXITS:

Exit / Escapes clear of obstructions
Exit signs & Emer lights properly lit

Pass	Fail	Notes:
	✓	2 Doors - Bind when opened

Fire Alarm System

Panel clear, accessible, operational

✓		
---	--	--

Fire Extinguishers

Extinguishers full & tagged annually
Extinguishers accessible

✓		
	✓	one extinguisher missing

Heating System

Boiler room clear of all combustibles
Boiler room properly rated/protected

✓		
✓		

Electrical system

Extension cord use vs. permanent
Electrical panels clear & accessible
Electrical circuits clearly identified

✓		
✓		
✓		

Sprinkler System

Sprinkler heads >18" of clearance
Sprinkler Rm & FDC labeled & clear
Spare heads & wrench supplied
Sprinkler system tagged insp. date

✓		
✓		
✓		
✓		

House Keeping

Furnishings & decorations flame rest
Art work displayed < 20% wall area
Housekeeping organized for safety

✓		
✓		
✓		

Additional Safety Concerns:



Portland Fire Department Monthly School Inspection

Name: <i>Reiche</i>	Address: <i>166 Brackett St.</i>
Principal: <i>Marcia Gendron</i>	Emergency contact # :

Date inspected: <i>9-14-09</i>	Inspector: <i>Capt. Dyer</i>
Time in: <i>1600</i>	Time out: <i>1630</i>

Fire Drills Conducted Yes No Date of last drill: *9-10-09 1400 hrs.*

EXITS:	Pass	Fail	Notes:
Exit / Escapes clear of obstructions	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Exit signs & Emer lights properly lit	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<i>1st floor, 2nd floor</i>

Fire Alarm System

Panel clear, accessible, operational	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
--------------------------------------	-------------------------------------	--------------------------	--

Fire Extinguishers

Extinguishers full & tagged annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Extinguishers accessible	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Heating System

Boiler room clear of all combustibles	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Boiler room properly rated/protected	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Electrical system

Extension cord use vs. permanent	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Electrical panels clear & accessible	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Electrical circuits clearly identified	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Sprinkler System

Sprinkler heads >18" of clearance	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Sprinkler Rm & FDC labeled & clear	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Spare heads & wrench supplied	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Sprinkler system tagged insp. date	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

House Keeping

Furnishings & decorations flame rest	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Art work displayed < 20% wall area	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Housekeeping organized for safety	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Additional Safety Concerns:

James Barter - Contact