



Portland Fire Department Monthly School Inspection

| | |
|----------------------------------|------------------------------|
| Name: <i>Reiche</i> | Address: <i>166 Brackett</i> |
| Principal: <i>Marcin Gendron</i> | Emergency contact #: |

| | |
|--------------------------------|------------------------------|
| Date inspected: <i>1-28-10</i> | Inspector: <i>Capt. Dyer</i> |
| Time in: <i>1645</i> | Time out: <i>1720</i> |

Fire Drills Conducted Yes No Date of last drill: *1-22-10*

EXITS:

| | Pass | Fail | Notes: |
|---------------------------------------|-------------------------------------|-------------------------------------|----------------------------------------------------------------------------------------|
| Exit / Escapes clear of obstructions | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <i>Emergency light - 1st floor Clark St. Health St. Corridor, Boys Locker room</i> |
| Exit signs & Emer lights properly lit | <input type="checkbox"/> | <input checked="" type="checkbox"/> | |

Fire Alarm System

| | | | |
|--------------------------------------|-------------------------------------|--------------------------|--|
| Panel clear, accessible, operational | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
|--------------------------------------|-------------------------------------|--------------------------|--|

Fire Extinguishers

| | | | |
|--------------------------------------|-------------------------------------|--------------------------|--|
| Extinguishers full & tagged annually | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| Extinguishers accessible | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |

Heating System

| | | | |
|---------------------------------------|-------------------------------------|--------------------------|--|
| Boiler room clear of all combustibles | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| Boiler room properly rated/protected | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |

Electrical system

| | | | |
|----------------------------------------|-------------------------------------|--------------------------|--|
| Extension cord use vs. permanent | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| Electrical panels clear & accessible | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| Electrical circuits clearly identified | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |

Sprinkler System

| | | | |
|------------------------------------|-------------------------------------|--------------------------|----------------|
| Sprinkler heads >18" of clearance | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| Sprinkler Rm & FDC labeled & clear | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| Spare heads & wrench supplied | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| Sprinkler system tagged insp. date | <input checked="" type="checkbox"/> | <input type="checkbox"/> | <i>1-12-10</i> |

House Keeping

| | | | |
|--------------------------------------|-------------------------------------|--------------------------|--|
| Furnishings & decorations flame rest | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| Art work displayed < 20% wall area | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |
| Housekeeping organized for safety | <input checked="" type="checkbox"/> | <input type="checkbox"/> | |

Additional Safety Concerns:

Keys in Knox Box do not open front door

Monthly School Inspection Form

Howard C Reiche School Company Ladder 6
 Address 166 Brackett St Month March 2010

| Hazards | Location and Number of Bad Conditions | | | | | | |
|------------------------------------------------------------------------------|---------------------------------------|-----|-----|-----|-----|-------|-------|
| | Bsmt. | 1st | 2nd | 3rd | 4th | Attic | Total |
| 1. Fire Doors propped open | NA | OK | OK | | | | |
| 2. Locked exits | | | | | | | |
| 3. Hallway, stairway, or exit obstructions | | | | | | | |
| 4. Stuck windows leading to fire escapes | | | | | | | |
| 5. Cars blocking fire escape drop ladders or ladder truck access to windows. | | | | | | | |
| 6. Sprinkler system closed | | | | | | | |
| 7. Fire door self closers broken or missing | | | | | | | |
| 8. Standpipe hose not ready for use | | | | | | | |
| 9. Fire extinguishers not ready for use or outdated. | | | | | | | |
| 10. Unnecessary rubbish accumulations | | | | | | | |
| 11. Poor housekeeping or excessive storage | | | | | | | |
| 12. Other | | | | | | | |
| Totals | | | | | | | |

Items 1 through 6 must be corrected before you leave the premises.

Did you give a verbal order? () Yes () No
 To: _____ Details: Emergency lighting by 2nd floor egress

Did you give a written order? () Yes () No
 To: _____ Details: _____

Date of Inspection 3/15/10 Inspector [Signature] # 54