



# Portland Fire Department Monthly School Inspection

Name: <i>Reiche</i>	Address: <i>166 Brackett St.</i>
Principal: <i>Paul Yarnevich</i>	Emergency contact #:
Date inspected: <i>3-30-11</i>	Inspector: <i>Capt. Oyer</i>
	Time in: <i>1615</i> Time out: <i>1628</i>

Fire Drills Conducted Yes  No  Date of last drill: *unknown*

### EXITS:

Exit / Escapes clear of obstructions  
Exit signs & Emer lights properly lit

Pass Fail

	✓

Notes:

*1st floor Rest 180,*

### Fire Alarm System

Panel clear, accessible, operational

✓	
---	--

### Fire Extinguishers

Extinguishers full & tagged annually  
Extinguishers accessible

✓	
✓	

### Heating System

Boiler room clear of all combustibles  
Boiler room properly rated/protected

✓	
✓	

### Electrical system

Extension cord use vs. permanent  
Electrical panels clear & accessible  
Electrical circuits clearly identified

✓	
✓	
✓	

### Sprinkler System

Sprinkler heads >18" of clearance  
Sprinkler Rm & FDC labeled & clear  
Spare heads & wrench supplied  
Sprinkler system tagged insp. date

✓	
✓	
✓	

*2-25-11*

### House Keeping

Furnishings & decorations flame rest  
Art work displayed < 20% wall area  
Housekeeping organized for safety

	✓
✓	
✓	

*MOOSE*

Additional Safety Concerns:



# Portland Fire Department Monthly School Inspection

Name: <i>Reiche School</i>	Address: <i>66 Brackett St.</i>
Principal: <i>Paul Yarnovich</i>	Emergency contact #:

Date inspected: <i>11-30-10</i>	Inspector: <i>Capt. Dyer</i>
Time in: <i>630</i>	Time out:

Fire Drills Conducted    Yes     No     Date of last drill: \_\_\_\_\_

### EXITS:

Exit / Escapes clear of obstructions  
Exit signs & Emer lights properly lit

Pass	Fail
	✓

### Notes:

*1st floor west side, across from health sta.  
2nd floor west, Boys locker rm.*

### Fire Alarm System

Panel clear, accessible, operational

✓	
---	--

### Fire Extinguishers

Extinguishers full & tagged annually  
Extinguishers accessible

✓	
✓	

### Heating System

Boiler room clear of all combustibles  
Boiler room properly rated/protected

✓	
✓	

### Electrical system

Extension cord use vs. permanent  
Electrical panels clear & accessible  
Electrical circuits clearly identified

✓	
✓	
✓	

### Sprinkler System

Sprinkler heads >18" of clearance  
Sprinkler Rm & FDC labeled & clear  
Spare heads & wrench supplied  
Sprinkler system tagged insp. date

✓	
✓	
✓	
✓	

*11-23-10*

### House Keeping

Furnishings & decorations flame rest  
Art work displayed < 20% wall area  
Housekeeping organized for safety

	✓
✓	
✓	

### Additional Safety Concerns:

*"Moose" artwork in entry*



# Portland Fire Department Monthly School Inspection

Name: <i>Reiche</i>	Address:
Principal:	Emergency contact #:

Date inspected: <i>12-27-11</i>	Inspector: <i>Capt Dyer</i>
Time in: <i>10:50</i>	Time out:

Fire Drills Conducted    Yes     No     Date of last drill: \_\_\_\_\_

EXITS:	Pass	Fail	Notes:
Exit / Escapes clear of obstructions	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Exit signs & Emer lights properly lit	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Fire Alarm System	Pass	Fail	Notes:
Panel clear, accessible, operational	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Fire Extinguishers	Pass	Fail	Notes:
Extinguishers full & tagged annually	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Extinguishers accessible	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Heating System	Pass	Fail	Notes:
Boiler room clear of all combustibles	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Boiler room properly rated/protected	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Electrical system	Pass	Fail	Notes:
Extension cord use vs. permanent	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Electrical panels clear & accessible	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Electrical circuits clearly identified	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Sprinkler System	Pass	Fail	Notes:
Sprinkler heads >18" of clearance	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Sprinkler Rm & FDC labeled & clear	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Spare heads & wrench supplied	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Sprinkler system tagged insp. date	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<i>11-23-11</i>

House Keeping	Pass	Fail	Notes:
Furnishings & decorations flame rest	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Art work displayed < 20% wall area	<input checked="" type="checkbox"/>	<input type="checkbox"/>	
Housekeeping organized for safety	<input checked="" type="checkbox"/>	<input type="checkbox"/>	

Additional Safety Concerns: