Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 07/12/16

Dale's Burner Service

207 423-4202 daleabrown@live.com 17 MESERVE CIRCLE , MAINE 04072

July 12, 2016

ROBERT WIENER
Preservation Compliance Coordinator
RWIENER @portlandmaine.gov
207 756-8023

I sent A Pitcher of vent Pipe back to you. this is the vent pipe and out door sensor. for second floor Boiler. which was installed last year. there going to be another one installed about eight feet below that vent for first floor boiler. and the third floor boiler is going to be vented through the Roof.

We will fix second floor vent pipe and install 1ST floor vent pipe at the same time.

It's Impossible To Vent out back as there is a three story deck in the way.

I hope this helps you , any question feel free to call or E-Mail me.

Sincerely yours,

Dale A Brown