

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND BUILDING PERMIT



This is to certify that

MARCHETTI MICHAEL P & BONITA D JTS

Located at

82 SPRUCE ST

PERMIT ID: 2013-01247

ISSUE DATE: 06/26/2013

CBL: 056 G007001

has permission to **Install 10 x 12 storage shed for tenants' bikes etc.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.	A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.
---	--

N/A

/s/ Tammy Munson

Fire Official

Building Official

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
THERE IS A PENALTY FOR REMOVING THIS CARD**

Approved Property Use - Zoning
four dwelling units

Building Inspections

Fire Department

BUILDING PERMIT INSPECTION PROCEDURES
Please call 874-8703 (ONLY)
or email: buildinginspections@portlandmaine.gov

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

REQUIRED INSPECTIONS:

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No: 2013-01247	Date Applied For: 06/17/2013	CBL: 056 G007001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
Proposed Use: 4 Unit	Proposed Project Description: Install 10 x 12 storage shed for tenants' bikes etc.			
Dept: Historic Status: Approved Reviewer: Deb Andrews Approval Date: 06/21/2013		Note: Ok to Issue: <input checked="" type="checkbox"/>		
Conditions: 1) Not readily visible from a public way.				
Dept: Zoning Status: Approved w/Conditions Reviewer: Ann Machado Approval Date: 06/17/2013		Note: Ok to Issue: <input checked="" type="checkbox"/>		
Conditions: 1) Section 105.2(1) of the International Building Code states that storage sheds 120 square feet or under are exempt from building code review. This structure has not been reviewed for codes or safety under the building code. The owner takes full responsibility for structural integrity. 2) The shed must be a minimum of five feet from the rear and side property lines. The maximum height allowed is 18 feet. 3) ANY exterior work requires a separate review and approval thru Historic Preservation. This property is located within an Historic District. 4) This property shall remain a four family dwelling. Any change of use shall require a separate permit application for review and approval.				