CITY OF PORTLAND, MAINE
RESURGAM
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 06/10/13

Picture of existing handrail showing height from landing. If deemed acceptable by historic it is our intention to patch in the existing handrail notch and raise the top of the new handrail to 36” minimum above the landing.