Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 06/10/13

Property Information:

Property number . . . : 0050029-000-000
Property name . . . . : 80 SPRUCE STREET
Address . . . . . : 0080 SPRUCE ST, PORTLAND ME 04102
Phone number . . . . : 000-000-0000

Inspection Information:

Inspection date . . . : 10/20/06
Inspection type . . . : ROUTINE INSPECTION
Inspector 1 name . : ROBERT D. EATON
Inspecting station : Bramhall Station
Inspecting shift . : Platoon 3
Inspecting apparatus: L6

Owner Information:

Owner name . . . . . : BETTENCOURT JOS EPH S &
Address . . . . . : 80 SPRUCE ST, PORTLAND ME 04102

**** VIOLATIONS ****

Violation number . : 1
Violation class . . . : Fire Doors
Violation type . . . : DOOR ASSEMBLIES IN EXIT STAIRS MUST BE 1-HOUR RATE D
Location . . . . . : all doors leading to common areas
Compliance date . . . : 4/19/03
Compliance remedy . : Per City Ordinance

Violation number . : 2
Violation class . . . : Electric Wiring
Violation type . . . : Ext. cord used for permanent wire
Code reference . . . : NFPA70
Location . . . . . : Under door to apt #3 front stairwell
Compliance date . . . : 11/21/06
Compliance remedy . : Per City Ordinance