



Statement of Deficiencies and Plan of Corrections

Facility Name: KIDDIE GARDEN, LLC
Location: 237 SPRING ST
PORTLAND, ME 04102-3712

Owner Name: 223 BRACKETT ST
Address: PORTLAND, ME 04102-3207

Telephone: +1 (207) 773-0426
Facility Type: GDC
File Number: 81523
Resource ID: 686365

During an inspection of your facility a certified State Inspector has found the following violations:

In this right hand column, you are required to indicate how and when you will have these violations corrected. Complete this information and return this "Plan of Correction" to the above address within 10 days of receipt of this statement.

| | | |
|--------------|---|--|
| 1. VIOLATION | Violations found as described Daycare Room requires a second means of escape, either a door or complaint Egress Window remotely located from main entrance. REFER ENCLOSED WINDOW SPEC SHEET | |
| 2. VIOLATION | Violations found as described Exposed romex present. Wires must be protected or removed. | |
| 3. VIOLATION | Violations found as described Stair to kitchen does not meet minimum riser/run requirements. (4 max riser 7"/minimum 4") REFER ENCLOSED STAIR SPEC SHEET. | |

Date of Inspection: 6/17/2015
Inspector: MICHAEL J. MINKOWSKI
Date Sent: 6/23/2015

Owner/Occupant Signature: _____
Date: _____