

Building Inspections - Fw: Lorna Leo daycare 237 Spring st, portland

From: "lorna" <wbsgram@maine.rr.com>
To: "Building Inspections" <buildinginspections@portlandmaine.gov>
Date: 8/17/2015 9:48 PM
Subject: Fw: Lorna Leo daycare 237 Spring st, portland
Attachments: WP_20150817_001.jpg

Hello, this is the email from the State Fire Marshal approving occupation for 237 Spring Street for the child daycare facility. Please note that Fire Marshal Minkowski accidentally wrote my home address (223 Brackett St) in the email. The inspection was indeed for 237 Spring Street.

Thank you for your help.
Lorna Leo

From: [Minkowsky, Michael J](#)
Sent: Monday, August 17, 2015 1:03 PM
To: [Craig Messinger](#)
Cc: [Lorna Leo](#)
Subject: FW: Lorna Leo daycare 237 Spring st, portland

Hi Lt.,

Regarding 223 Brackett St. Portland, Lorna Leo. Mrs. Leo has satisfied the requirements of the FMO i.e. egress window, railing install and remove exposed wiring. I will put the approval paperwork in today. If there is anything we can do on this end to facilitate this project for the Leo's please let me know.

Mike

From: Lorna Leo [mailto:wbsgram@maine.rr.com]
Sent: Monday, August 17, 2015 11:22 AM
To: Minkowsky, Michael J
Subject: Lorna Leo daycare 237 Spring st, portland

Egress window installed. Egress opening is 26x42.