

057-B-007

Inspection Services
Samuel P. Hoffses
Chief



Planning and Urban Development
Joseph E. Gray Jr.
Director

CITY OF PORTLAND

October 29, 1992

Gregg Lipton
1 Millridge Rd
Cumberland, ME 04021

Re: 24 Taylor St
CBL #: 057-B-007
DU: 2

Dear Mr. Lipton,

The Housing Inspections Division of the Department of Planning and Urban Development has recently completed an overall inspection of the above referred property.

Congratulations are extended to you for the general condition of your property which was found to meet the standards established by the City's Housing Code. We did, however, note the following items that could cause future problems.

- 1. Remove or encapsulate friable asbestos in cellar within 60 days. 116-6

Good maintenance is the best way to protect the value of your property and neighborhood.

Please feel free to call on us if we can be of assistance to you.

Sincerely,

Kelove
Kathleen Lowe
Code Enforcement Officer

P Samuel Hoffses
P. Samuel Hoffses
Chief of Inspection Services