

Jonathan Rioux - Re: 12 Taylor St comments

From: "mail.artofspace.com" <chris@artofspace.com>
To: "Jonathan Rioux" <JRIOUX@portlandmaine.gov>
Date: 7/16/2013 3:04 PM
Subject: Re: 12 Taylor St comments

Jonathan;

The maximum span for **2x8 @ 16" o.c. is 12'-7"** using Hem-Fir #1 for a standard residential living load (40psf LL and a 10 psf) The floor system is spanning 8'-3" at its deepest point.

I'm not sure about your comment on sheet A1. I am presuming it is about the 42" guard rail, where Historic would like it at 36" without the top pipe rail. I show it with the 42" pipe rail so that we can have that discussion with both options on the table. Please call to discuss.

Thank you,

Chris

Christopher Delano, Architect, AIA
website: www.artofspace.com
207.892.1643

On Jul 16, 2013, at 2:22 PM, Jonathan Rioux wrote:

Please see the attached pdf file.

Jonathan Rioux
Code Enforcement Officer/ Plan Reviewer

City of Portland
Planning and Urban Development Department
Inspection Services Division
389 Congress St. Rm 315
Portland, ME 04101
Office: 207.874.8702
Support Staff: 207.874.8703
jrioux@portlandmaine.gov

Notice: Under Maine law, documents - including e-mails - in the possession of public officials or city employees about government business may be classified as public records. There are very few exceptions. As a result, please be advised that what is written in an e-mail could be released to the public and/or the media if requested.

<14Taylor-A1PERMIT.pdf><14Taylor-A2PERMIT.pdf>