



Portland Fire Department

VALERIE GUILLET

RE: 273 DANFORTH ST
PORTLAND, ME

057 B019001

273 DANFORTH ST Page 1 of 2

**NOTICE OF VIOLATION
AND ORDER TO CORRECT**

To Whom it May Concern,

The City of Portland inspected the above-referenced property on 4/19/2018 and found violations of the City of Portland Code of Ordinances, which are listed on the attached page(s). You are hereby ordered to correct these violations by the dates given on the attached.

A reinspection of your property will take place on 9/13/2018 10:00:00AM .

Please contact the Fire Prevention Bureau at 874-8400 if you have any question about your reinspection. If the violations are not corrected at the time of reinspection, you will be charged a \$150 failed reinspection fee.

If you do not correct the attached violations, then this matter may be referred to the City of Portland Corporation Counsel for legal action, including civil penalties and other legal remedies.

Thank you for keeping the City of Portland safe.

Sincerely,

Captain John Brennan
Fire Prevention Bureau
City of Portland

NON-COMPLIANCE VIOLATION LIST

NAME	CODE DESCRIPTION	COMMENTS	Deadline
PFD Rules, 4.6	Unit or suite numbers must be clearly marked on doors, with the first numeral of each residential unit being the floor designation.	All aptments front and rear entry doors.	7/31/2018
NFPA 101-31.3.2	Boiler and fuel-fired heaters serving more than one dwelling unit must have 1-hour separation or sprinkler protection.	All fuel fired appliances in the basement must have sprinkler protection.	8/31/2018
NFPA 101-31.2.2.1	1-hour fire rated doors and assemblies required, including self-closing and self-latching mechanisms.	Apartment 2 front and rear door.	8/31/2018