


267½ Danforth Street

NDP-REH/B II



Loc. 267 1/2 Danforth Street  
Proj: NDP 2  
BLOCK: 57B  
Issued: August 10, 1971 Expires: Sept. 10, 1971

Mr. John Conley  
267 1/2 Danforth Street  
Portland, Maine

ROOM 315, CITY HALL  
PORTLAND, MAINE 04111  
774-8221

Board of Commissioners  
PAUL M. FOLAN, Chairman  
HORACE M. BUDD, Vice Chairman  
JOHN H. MALCONIAN  
THE REVEREND HAROLD A. McELWAIN  
CHARLES W. REDMAN, JR.  
THOMAS F. VALLEAU, Executive Director

Dear Mr. Conley:

An examination was made on August 10, 1971, of the premises located at 267 1/2 Danforth St., Portland, Maine by Rehabilitation Specialist Max Furrer. Violations of Municipal Codes relating to housing conditions were found as described below.

In accordance with the provisions of the above mentioned codes you are required to correct these defects on or before Sept. 10, 1971. Some repairs or improvements will require permits which are obtained from the Building, Health, Fire or other City Departments.

Financial assistance and construction advice are available from the federal government, by contacting the Neighborhood Development Program office at 247 Danforth Street, 774-3611. Please call us to discuss these before beginning work on your property.

Very truly yours,

*Gregory E. Fay, R/oh*

Project Director

BY: *Richard E. Furrer*  
Chief, Rehabilitation Services

VIOLATIONS

HOUSING CODE REFERENCE

Exterior

1. Point up all eroded mortar joints in foundation walls. 3A
2. Repair or replace all broken or cracked front step stairtreads. 3D

3. Repair or replace the defective gutter and downspouts at front of structure. 3A
4. Repair flaky ceiling in hall.
5. Replace the deteriorated roof at left side front of structure 3A
6. Repair or replace the defective brick and mortar on chimney in cellar. 3E

Interior

1. Disconnect the extension cord(s) being used unlawfully in upstairs bedrooms. 8D