#### DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

METCALF MARK

Located at

224 SPRING ST

**PERMIT ID:** 2014-02918

**ISSUE DATE:** 01/06/2015

CBL: 057 D004001

has permission to For the installation of an HVAC System (gas, direct vent).

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Benjamin Wallace Jr.

/s/ Tammy Munson

Fire Official

**Building Official** 

### THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

**Building Inspections** 

Fire Department

## BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

# Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

#### **REQUIRED INSPECTIONS:**

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-871			Permit No: 2014-02918	Date Applied For: 12/18/2014	CBL:	
					057 D004001	
Proposed Use:		Proposed	<b>Project Description:</b>			
Same: Four- (4-) Family Home			For the installation of an HVAC System (gas, direct vent).			
<b>Dept:</b> Historic	Status: Approved w/Conditions	Reviewer:	Robert Wiener	Approval Da	_	
Note:					Ok to Issue: 🗹	
<b>Conditions:</b>						
1) Building owner is exterior wall.	expected to maintain shrubs at the front co	orner of the bu	ilding to screen the	e utilities that are mo	unted on the	
2) Wall cap and exter installation.	ior mounting accessory are to be painted t	to match the si	ding color. If poss	sible, paint should be	applied before	
Dept: Zoning	Status: Approved w/Conditions	Reviewer:	Tammy Munson	Approval Da	nte: 12/29/2014	
Note:					Ok to Issue: 🗹	
<b>Conditions:</b>						
1) This approves the	installation of the heating unit only. It doe	s not verify the	e legal use of the b	uilding.		
Dept: Building	Status: Approved w/Conditions	Reviewer:	Tammy Munson	Approval Da	nte: 12/29/2014	
Note:					Ok to Issue:	
<b>Conditions:</b>						
1) The installation mu	ast comply with the State of Maine Gas Re	egulations.				
2) Equipment shall be	e installed in compliance with the manufac	cturer's specific	cations and the UL	listing.		
Dept: Fire	Status: Approved w/Conditions	Reviewer:	Benjamin Wallace	e Jr. Approval Da	nte: 12/29/2014	
Note:					Ok to Issue: 🗹	
<b>Conditions:</b>						
1) Installation shall co	omply with NFPA 211 Standard for Chim	nevs Firenlac	es Vents and Sol	id Fuel_Rurning An	nliances: NFPA	

- 1) Installation shall comply with NFPA 211, Standard for Chimneys, Fireplaces, Vents, and Solid Fuel–Burning Appliances; NFPA 54, National Fuel Gas Code; NFPA 70, National Electrical Code; and the manufacturer's published instructions.
- 2) Installation shall comply with City Code Chapter 10. Boiler protection is required.