Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 08/08/17

Replace Rotted Deck Boards

Replace Rotted Framing

Add Joist Hangers & Lags

Replace Railing To Code 4' O.C.

Replace Railings with 4" O.C. Balusters

Rotted only - 16" O.C. Replace 2x8"

Replace Rotted 5/4" Decking