

**Benjamin Wallace - Re: 90 Brackett Street**

---

**From:** Benjamin Wallace  
**To:** Marc Foster  
**Date:** 6/27/2011 2:37 PM  
**Subject:** Re: 90 Brackett Street  
**CC:** Curt Magnuson  
**Attachments:** Benjamin Wallace.vcf

---

Ok, approved as follows:

Boiler protection and CO alarms within 3 weeks and basement fire door by July 1, 2012;

All remaining fire doors by July 1, 2013.

Please let us know when you can have the fire company back to check the boiler protection and CO alarms.

Thanks,

Lt. Benjamin Wallace Jr.  
Fire Prevention Officer  
Portland Fire Department  
380 Congress Street  
Portland, Maine 04101  
(207)756-8096

wallaceb@portlandmaine.gov>>> Marc Foster <fostema@gmail.com> 6/22/2011 4:18 PM >>>

Ben,

In response to the Fire Department's letter dated 6/10/2011 and also from our conversation today I am outlining our 2 year plan to bring the property at 90 Brackett Street into compliance.

Year 1: Boiler protection, 3 CO detectors, and Basement Fire Door

Year 2: 2 remaining fire doors

I greatly appreciate your understanding my financial situation regarding this property.

--

Marc C. Foster  
207.408.5789