



Reviewed for Code Compliance  
Inspections Division  
Approved with Conditions  
10/13/17

Date: \_\_\_\_\_

# NEXIUS

Accelerating Network and Business Transformation

April 4, 2017

Verizon Wireless  
400 Friberg Parkway  
Westborough, MA 01581

Ref.: Structural Analysis & Design  
Verizon Wireless Site Ref. Portland 9  
284 Danforth Street  
Portland, ME 04102  
Latitude: 43.646183° N  
Longitude: 70.266519° W

To Whom It May Concern:

Nexius Solutions, Inc. has performed the structural analysis and design for the new elevated platform supporting the proposed Verizon Wireless (VZW) equipment. This analysis also includes the design of the new custom made non-penetrating roof ballast antenna mounts at the above referenced site. The purpose of this analysis is to determine the structural adequacy of the building roof structure (upper and lower roof).

The proposed upper roof antenna installation consists of two sectors with non-penetrating ballast mounts holding a total of eight (8) Commscope SBNHH-1D65 panel antennas (96.6" H x 11.9" W x 7.1" D, 49.6 lb.), two (2) Nokia 4x30-B13 – remote radio heads (21.6" H x 12" W x 9" D, 57.2 lb.), two (2) Nokia 4x30-B25 – remote radio heads (25.8" H x 12" W x 7.3" D, 57.0 lb.), two (2) Nokia 4x45-AWS – remote radio heads (25.6" H x 12" W x 7.3" D, 67 lb.) and related cables and hardware. The proposed lower roof antenna installation consists of four (4) Commscope SBNHH-1D65 panel antennas (96.6" H x 11.9" W x 7.1" D, 49.6 lb.), one (1) Nokia 4x30-B13 – remote radio head (21.6" H x 12" W x 9" D, 57.2 lb.), one (1) Nokia 4x30-B25 – remote radio head (25.8" H x 12" W x 7.3" D, 57.0 lb.), one (1) Nokia 4x45-AWS – remote radio head (25.6" H x 12" W x 7.3" D, 67 lb.) and related cables and hardware all mounted with side by side mounting frames to the proposed VZW equipment platform guardrails.

NEXIUS MA Office: 7 A Lyberty Way, Westford, MA 01886



Reviewed for Code Compliance  
Inspections Division  
Approved with Conditions  
Date: 10/13/17

# NEXIUS

Accelerating Network and Business Transformation

The proposed Verizon Wireless platform equipment will consist of one (1) MTU 20KW natural gas generator; one (1) Charles universal broadband enclosure; one (1) Battery cabinet and related cables and hardware.

This analysis considered the effects of wind load, snow load and dead load in accordance with the 2009 International Building Code as amended by the Maine Uniform Building and Energy Code.

Based on the structural analysis performed for the aforementioned site (see attached document), it is our opinion that the existing roof structure can safely support the proposed Verizon Wireless equipment (Equipment platform and the non-penetrating ballast frames). It is assumed that the existing structure has been well maintained and is in good condition. In addition, it is assumed that all proposed equipment will be installed in accordance with manufacturers' specifications.

If you have any questions or need further assistance, please contact this office.

Sincerely,

Ronald J. Jackson, P.E.  
National Director of A&E Services  
(774) 266-5050



Sahnoune Abed  
Lead Engineer  
(774) 266-6918



Applicable Codes:

- 2009 International Building Code (IBC)
- ASCE 7-10 Minimum Design Loads for Buildings and Other Structures
- AISC Steel Construction Manual (13th Ed.)
- TIA-222-G Structural Standards for Steel Antenna Towers and Antenna Supporting Structures

Scope of Calculation: VZW new steel equipment platform design and antenna ballast mount design. Existing building roof analysis.

Design Criteria:

Basic Wind Velocity,  $V = 100$  mph  
Ground Snow Loads,  $P_g = 50$  psf  
Radial ice thickness,  $t_i = 1.0$  in  
Density of ice,  $\gamma_i = 56$  pcf  
Exposure B  
Occupancy Category Class IV (Communication, emergency response)  
Topography Category: 1  
Structure Type: Rooftop

Equipment Specifications: (Source: Email dated 3/30/17)

1. SBNHH-1D65C (LxWxD): 96.6"x11.9"x7.1"	Net Weight = 49.6 lbf
2. Nokia 4x30-B13 (700 MHz) (LxWxD): 21.6"x12"x9"	Net Weight = 57.2 lbf
3. Nokia 4x30-B25 (1900 MHz) (LxWxD): 25.8"x12"x7.3"	Net Weight = 57.0 lbf
4. Nokia 4x45-AWS (2100 MHz) (LxWxD): 25.6"x12"x7.3"	Net Weight = 67.0 lbf

**Units:**

$psf := \frac{lbf}{ft^2}$       kips := 1000 lbf

- Gust Factor for Pole Structure,  $G_h := 1.0$  (Appurtenances)
- Ground Snow Load  $P_g := 50$  psf
- Importance factor,  $I_s := 1.2$
- Exposure factor,  $C_e := 1.0$
- Thermal factor,  $C_t := 1.2$
- Wind Speed,  $V := 100$  mph
- Importance factor,  $I_w := 1.15$
- Wind Direction Probability Factor,  $K_d := 0.95$
- Exposure Category Coefficients (Table 2-4, TIA-222-G):

$Z_g := 1200$  ft (Exposure B)       $\alpha := 7.0$  (Exposure B)       $K_{zmin} := 0.70$  (Exposure B)

- Topographic Category Coefficients (Table 2-5, TIA-222-G):

$K_t := 1.0$        $K_{zt} := 1.0$       &       $f := 1.0$



- Wind Force on Appurtenances:

$$Z_{\alpha\gamma} := 84 \text{ ft} \quad (\text{Antenna height above ground for Alpha \& Gamma sectors})$$

$$Z_{\beta} := 68.5 \text{ ft} \quad (\text{Antenna height above ground for Beta sector})$$

$$Z_{RRH} := 80.5 \text{ ft} \quad (\text{RRH height above ground for Alpha \& Gamma sectors})$$

- Velocity pressure coefficient:

$$K_{z\alpha\gamma} := 2.01 \cdot \left( \frac{Z_{\alpha\gamma}}{Z_g} \right)^{\frac{2}{\alpha}} \quad K_{z\alpha\gamma} = 0.94$$

$$K_{z\beta} := 2.01 \cdot \left( \frac{Z_{\beta}}{Z_g} \right)^{\frac{2}{\alpha}} \quad K_{z\beta} = 0.89$$

$$K_{z_{RRH}} := 2.01 \cdot \left( \frac{Z_{RRH}}{Z_g} \right)^{\frac{2}{\alpha}} \quad K_{z_{RRH}} = 0.93$$

- Velocity pressure,  $q_{z_{\alpha\gamma}} := .00256 \cdot K_{z\alpha\gamma} \cdot K_{zt} \cdot K_d \cdot V^2 \cdot I_w \cdot \text{psf}$   $q_{z_{\alpha\gamma}} = 26.3 \text{ psf}$

$$q_{z_{\beta}} := .00256 \cdot K_{z\beta} \cdot K_{zt} \cdot K_d \cdot V^2 \cdot I_w \cdot \text{psf} \quad q_{z_{\beta}} = 24.8 \text{ psf}$$

$$q_{z_{RRH}} := .00256 \cdot K_{z_{RRH}} \cdot K_{zt} \cdot K_d \cdot V^2 \cdot I_w \cdot \text{psf} \quad q_{z_{RRH}} = 26 \text{ psf}$$

(P) Antennas:

1. SBNHH-1D65C

$$L_{Ant} := 96.6 \text{ in} \quad W_{Ant} := 11.9 \text{ in} \quad D_{Ant} := 7.1 \text{ in} \quad Wt_{Ant} := 49.6 \text{ lbf}$$

$$Area_{Ant} = L_{Ant} \cdot W_{Ant} \quad Area_{Ant} = 7.98 \text{ ft}^2$$

Aspect Ratio,  $AR_{Ant} := \frac{L_{Ant}}{W_{Ant}} \quad AR_{Ant} = 8.12$

$$C_{a_{Ant}} := 1.4 + \left( \left( \frac{2.0 - 1.4}{25 - 7} \right) \right) \cdot ((AR_{Ant} - 7)) \quad C_{a_{Ant}} = 1.44$$

$$EPA_{Ant} := C_{a_{Ant}} \cdot Area_{Ant} \quad EPA_{Ant} = 11.47 \text{ ft}^2$$

Weight\_of\_Antenna :=  $Wt_{Ant} \cdot 1.15$  (15% hardware & misc.)

$$D_{Ant} := \text{Weight\_of\_Antenna} = 57 \text{ lbf} \quad D_{Ant} = 57 \text{ lbf}$$



- Wind Force on Panel Antenna for Alpha & Gamma sectors mounted to proposed ballast mounts,

$$F_{Ant_{\alpha\gamma}} := q_{z_{\alpha\gamma}} \cdot G_h \cdot EPA_{Ant} \quad F_{Ant_{\alpha\gamma}} = 302 \text{ lbf}$$

$$F_{Ant_{\alpha\gamma}} = 302 \text{ lbf} \quad h_{Ant_{\alpha\gamma}} := 6 \text{ ft} \quad (\text{Above Roof Base})$$

- Wind Force on Panel Antenna for Beta sector attached to proposed guardrails,

$$F_{Ant_{\beta}} := q_{z_{\beta}} \cdot G_h \cdot EPA_{Ant} \quad F_{Ant_{\beta}} = 285 \text{ lbf}$$

$$F_{Ant_{\beta}} = 285 \text{ lbf} \quad h_{Ant_{\beta}} := Z_{\beta} = 69 \text{ ft} \quad (\text{Above Ground})$$

2. 700 RRH (RRH\_1)

$$L_{RRH_1} := 21.6 \text{ in} \quad W_{RRH_1} := 12 \text{ in} \quad D_{RRH_1} := 9 \text{ in} \quad Wt_{RRH_1} := 57.2 \text{ lbf}$$

$$Area_{RRH_1} := L_{RRH_1} \cdot W_{RRH_1} \quad Area_{RRH_1} = 1.8 \text{ ft}^2$$

$$\text{Aspect Ratio, } AR_{RRH_1} := \frac{L_{RRH_1}}{W_{RRH_1}} \quad AR_{RRH_1} = 1.8$$

$$C_{a_{RRH_1}} := 1.2 \quad (\text{TIA-222-G, Table 2-8})$$

$$EPA_{RRH_1} := C_{a_{RRH_1}} \cdot Area_{RRH_1} \quad EPA_{RRH_1} = 2.16 \text{ ft}^2$$

$$\text{Total\_Weight\_of\_RRH\_1} := Wt_{RRH_1} \cdot 1.15 \quad (15\% \text{ hardware \& misc.})$$

$$D_{RRH_1} := \text{Total\_Weight\_of\_RRH\_1} = 66 \text{ lbf}$$

$$\text{Wind Force on RRH\_1, } F_{RRH_1} := q_{z_{RRH}} \cdot G_h \cdot EPA_{RRH_1}$$

$$F_{RRH_1} = 56 \text{ lbf} \quad h_{RRH_1} := 30 \text{ in} \quad (\text{Above Roof Base})$$

3. 1900 RRH (RRH\_2)

$$L_{RRH_2} := 25.8 \text{ in} \quad W_{RRH_2} := 12 \text{ in} \quad D_{RRH_2} := 7.3 \text{ in} \quad Wt_{RRH_2} := 57 \text{ lbf}$$

$$Area_{RRH_2} := L_{RRH_2} \cdot W_{RRH_2} \quad Area_{RRH_2} = 2.15 \text{ ft}^2$$

$$\text{Aspect Ratio, } AR_{RRH_2} := \frac{L_{RRH_2}}{W_{RRH_2}} \quad AR_{RRH_2} = 2.15$$



$$C_{a\_RRH\_2} := 1.2 \quad (\text{TIA-222-G, Table 2-8})$$

$$EPA_{RRH\_2} := C_{a\_RRH\_2} \cdot Area_{RRH\_2} \quad EPA_{RRH\_2} = 2.58 \text{ ft}^2$$

$$\text{Total\_Weight\_of\_RRH\_2} := Wt_{RRH\_2} \cdot 1.15 \quad (15\% \text{ hardware \& misc.})$$

$$D_{RRH\_2} := \text{Total\_Weight\_of\_RRH\_2} = 66 \text{ lbf}$$

$$\text{Wind Force on RRH}_2, \quad F_{RRH\_2} := q_{z\_RRH} \cdot G_h \cdot EPA_{RRH\_2}$$

$$F_{RRH\_2} = 67 \text{ lbf} \quad h_{RRH\_2} := 30 \text{ in} \quad (\text{Above Roof Base})$$

4. 2100 RRH, (RRH\_3)

$$L_{RRH\_3} := 25.6 \text{ in} \quad W_{RRH\_3} := 12 \text{ in} \quad D_{RRH\_3} := 7.3 \text{ in} \quad Wt_{RRH\_3} := 67 \text{ lbf}$$

$$Area_{RRH\_3} := L_{RRH\_3} \cdot W_{RRH\_3} \quad Area_{RRH\_3} = 2.13 \text{ ft}^2$$

$$\text{Aspect Ratio, } AR_{RRH\_3} := \frac{L_{RRH\_3}}{W_{RRH\_3}} \quad AR_{RRH\_3} = 2.13$$

$$C_{a\_RRH\_3} := 1.2 \quad (\text{TIA-222-G, Table 2-8})$$

$$EPA_{RRH\_3} := C_{a\_RRH\_3} \cdot Area_{RRH\_3} \quad EPA_{RRH\_3} = 2.56 \text{ ft}^2$$

$$\text{Total\_Weight\_of\_RRH\_3} := Wt_{RRH\_3} \cdot 1.15 \quad (15\% \text{ hardware \& misc.})$$

$$D_{RRH\_3} := \text{Total\_Weight\_of\_RRH\_3} = 77 \text{ lbf}$$

$$\text{Wind Force on RRH}_3, \quad F_{RRH\_3} := q_{z\_RRH} \cdot G_h \cdot EPA_{RRH\_3}$$

$$F_{RRH\_3} = 67 \text{ lbf} \quad h_{RRH\_3} := 30 \text{ in} \quad (\text{Above Roof Base})$$

5. DB-B1-6C-12AB-0Z (OVP)

$$L_{OVP} := 21.5 \text{ in} \quad W_{OVP} := 15.73 \text{ in} \quad D_{OVP} := 10.31 \text{ in} \quad Wt_{OVP} := 32 \text{ lbf}$$

$$Area_{OVP} := L_{OVP} \cdot W_{OVP} \quad Area_{OVP} = 2.35 \text{ ft}^2$$

$$\text{Aspect Ratio, } AR_{OVP} := \frac{L_{OVP}}{W_{OVP}} \quad AR_{OVP} = 1.37$$

$$C_{a\_OVP} := 1.2 \quad (\text{TIA-222-G, Table 2-8})$$



$$EPA_{OVP} := C_{a_{OVP}} \cdot Area_{OVP}$$

$$EPA_{OVP} = 2.82 \text{ ft}^2$$

$$Total\_Weight\_of\_OVP := Wt_{OVP} \cdot 1.15$$

(15% hardware & misc.)

$$D_{OVP} := Total\_Weight\_of\_OVP = 37 \text{ lbf}$$

Wind Force on OVP,

$$F_{OVP} := q_{z,RRH} \cdot G_h \cdot EPA_{OVP}$$

$$F_{OVP} = 73 \text{ lbf}$$

$$h_{OVP} := 30 \text{ in}$$

(Above Roof Base)

Required number of ballasts for sector Alpha & Gamma Antenna (See attached calculations):

N: Number of antenna

$$N := 4$$

N': Number of tray


$$N' := 4$$

$$Total\_WindLoad := N \cdot F_{Ant_{\alpha\gamma}} = 1207 \text{ lbf}$$

FS: Factor of Safety

$$SF := 1.5$$

Assume 4"x8"x16" Solid Concrete Block weighs approx. 30 lbf.





Calculation of required ballast weights for the proposed ballast frame

Total wind load		1207	lbf		
Overturning arm length		8	ft		
Factor of Safety (FS)		1.5			
Overturning moment		14482	lbf-ft		
Overturning resistant weights					
4.89		lbf/ft	L3x3x1/4 angle		
18		lbf/ft	W8x18 beam		
	length	sections	weight	moment arm length	Resistant moment
	ft	-	lbf	ft	lbf*ft
Part#1	7	3	378	3	1134
Part#2	12	1	216	6	1296
Part#3	7	3	378	9	3402
Part#4	12	1	216	12	2592
Part#7	7	2	68.46	2.25	154
Part#8	7	2	68.46	3.75	257
Part#9	7	2	68.46	8.25	565
Part#10	7	2	68.46	9.75	667
Subtotal			1462	Subtotal	10067
Ballast weights					
			weight	arm length	Resistant moment
			lbf	ft	lbf*ft
Tray#1			W	3.5	3.5W
Tray#2			W	3.5	3.5W
Tray#3			W	10.5	10.5W
Tray#4			W	10.5	10.5W
Subtotal					28W
Required resistant moment for 28W=					4415 lbf-ft
W					184 lbf
Weight per ballast weight					30 lbf
Ballast weights required					6 per tray
Provided					7 per tray
O.K.					

- Snow Loads

$P_g = 50 \text{ psf}$        $I_s := 1.2$        $C_e := 1.0$        $C_t := 1.2$

$P_f := 0.7 \cdot C_e \cdot C_t \cdot I_s \cdot P_g = 50.4 \text{ psf}$

(E) Roof Loads,       $T.A_{avg} := 4 \text{ ft} + 8 \text{ in} = 4.67 \text{ ft}$

DL,	Roofing materials	2.0 psf
	Decking	2.0 psf
	Rigid Insulation	1.0 psf
	Steel Joists	2.0 psf
	Misc.	8.0 psf
	<b>Total DL</b>	<b>15.0 psf</b>



SL, Snow Load 50.0 psf

$$\text{Total\_Ant\_Dead\_Load} := N \cdot D\_Ant = 228 \text{ lbf}$$

$$\text{Total\_RRH\&OVP\_Dead\_Load} := D_{RRH\_1} + D_{RRH\_2} + D_{RRH\_3} + D_{OVP}$$

$$\text{Total\_DeadLoad} := \text{Total\_Ant\_Dead\_Load} + \text{Total\_RRH\&OVP\_Dead\_Load} = 473 \text{ lbf}$$

$$\text{Total\_Ballast\_Blocks} := 7 \cdot N' \cdot 30 \text{ lbf} = 840 \text{ lbf}$$

$$\text{Total\_DL\_BallastMount} := 1315 \text{ lbf} \cdot 1.10 = 1447 \text{ lbf}$$

$$\text{BallastMount\_Area} := 196 \cdot \text{ft}^2$$

$$\text{Total\_Unit\_DeadLoad} := \frac{(\text{Total\_DeadLoad} + \text{Total\_Ballast\_Blocks} + \text{Total\_DL\_BallastMount})}{\text{BallastMount\_Area}}$$

$$\text{Total\_Unit\_DeadLoad} = 14 \text{ psf} \quad \text{DL}_{\text{ballast\_mount}} := \text{Total\_Unit\_DeadLoad} \cdot T.A_{\text{avg}} = 66 \text{ plf}$$

DL := 15 psf      SL := 50 psf

Load Combination:

$$\text{LC}_1 = \text{DL}$$

$$\text{LC}_2 = \text{DL} + \text{SL}$$

$$(\text{DL} \cdot T.A_{\text{avg}} + \text{DL}_{\text{ballast\_mount}}) = 136 \text{ plf}$$

$$(\text{DL} + \text{SL}) \cdot T.A_{\text{avg}} + \text{DL}_{\text{ballast\_mount}} = 369 \text{ plf}$$

l := 27 ft      16H6 steel joist

$$w_{u\_1} := (\text{DL} + \text{SL}) \cdot T.A_{\text{avg}} = 303 \text{ plf}$$

$$w_{u\_2} := \text{DL}_{\text{ballast\_mount}} = 66 \text{ plf}$$

$$R_{\text{max}} := 4.71 \text{ kip}$$

$$M_{\text{max}} := 30.03 \text{ ft} \cdot \text{kip} \quad @ 14 \text{ ft } +/-$$

$$w_{\text{equ}} := \frac{8 \cdot M_{\text{max}}}{l^2} = 330 \text{ plf}$$

16H6 Steel Joist Allowable Capacity = 315 plf Engineering practice allows 5% overstress. Thus, the roof joists are adequate to support the custom made non penetrating ballast antenna mounts



Design of new VZW equipment steel platform on top of lower roof

VZW Equipment Platform Specifications:

$$A_{Platform} := 200 \text{ ft}^2$$

- |   |                       |
|---|-----------------------|
| 1. Charles CUBE universal broadband enclosure | Weight = 1000 lbf     |
| 2. Battery Cabinet                            | Weight = 2500 lbf     |
| 3. Natural Gas Generator                      | Weight = 2200 lbf     |
| 4. Telco & Power Cabinets (Misc.)             | Est. Weight = 250 lbf |

$$DL_{radio} := 1000 \text{ lbf} \quad DL_{batt} := 2500 \text{ lbf} \quad DL_{Gen} := 2200 \text{ lbf} \quad DL_{Misc} := 250 \text{ lbf}$$

$$DL_{eqpt} := (DL_{radio} + DL_{batt} + DL_{Gen} + DL_{Misc}) \cdot 1.15 = 6843 \text{ lbf} \quad (15\% \text{ cabling \& misc.})$$

$$Grating\_UnitWt := 10 \text{ psf} \quad DL_{Grat} := Grating\_UnitWt \cdot A_{Platform} = 2000 \text{ lbf}$$

$$UnitWt\_LL := 10 \text{ psf} \quad (\text{Technician \& tools}) \quad LL := UnitWt\_LL \cdot A_{Platform} = 2000 \text{ lbf}$$

$$SL := 50 \text{ psf} \quad SL_{Platform} := SL \cdot A_{Platform} = 10000 \text{ lbf}$$

Load Combinations: (Allowable Stress Design)

- LC1: DL  
LC2: DL + LL  
LC3: DL + SL  
LC4: DL + 0.75LL + 0.75SL

$$LC1 := DL_{eqpt} + DL_{Grat} = 8843 \text{ lbf}$$

$$LC2 := DL_{eqpt} + DL_{Grat} + LL = 10843 \text{ lbf}$$

$$LC3 := DL_{eqpt} + DL_{Grat} + SL_{Platform} = 18843 \text{ lbf} \quad (\text{Controlling})$$

$$LC4 := DL_{eqpt} + DL_{Grat} + 0.75 \cdot LL + 0.75 \cdot SL_{Platform} = 17843 \text{ lbf}$$

Design of Beam B1

$$L_{B1} := 10 \text{ ft} \quad TA_{B1} := 3 \text{ ft} \quad Fy := 50 \text{ ksi}$$

$$UL_{B1} := \frac{LC3}{A_{Platform}} \cdot TA_{B1} = 283 \text{ plf}$$

$$R_{max\_B1} := UL_{B1} \cdot \frac{L_{B1}}{2} = 1.41 \text{ kip} \quad M_{max\_B1} := UL_{B1} \cdot \frac{L_{B1}^2}{8} = 3.53 \text{ kip} \cdot \text{ft}$$

Try W8x18:

$$L_{b\_B1} := 3 \text{ ft} + 4 \text{ in} \quad Z_{x\_B1} := 17 \text{ in}^3 \quad L_{p\_B1} := 4.34 \text{ ft} \quad L_{r\_B1} := 13.5 \text{ ft}$$

$$S_{x\_B1} := 15.2 \text{ in}^3 \quad I_{x\_B1} := 61.9 \text{ in}^4 \quad C_b := 1.0 \quad (\text{Assumed}) \quad \Omega := 1.67$$



$$M_{r\_B1} := 531.1 \text{ kip}\cdot\text{in} \quad M_{p\_B1} := 849.7 \text{ kip}\cdot\text{in}$$

$$M_{n\_B1} := C_b \cdot \left( M_{p\_B1} - (M_{p\_B1} - M_{r\_B1}) \cdot \left( \frac{L_{b\_B1} - L_{p\_B1}}{L_{r\_B1} - L_{p\_B1}} \right) \right) = 885 \text{ kip}\cdot\text{in}$$

$$\frac{M_{n\_B1}}{\Omega} = 44.1 \text{ kip}\cdot\text{ft} > M_{\max\_B1} = 3.5 \text{ kip}\cdot\text{ft}$$

Design of Beam B2

$$L_{B2} := 10 \text{ ft} \quad a_{B2} := 4 \text{ ft} \quad R_{\max\_B1} = 1.41 \text{ kip}$$

$$R_{\max\_B2} := 2 \cdot R_{\max\_B1} = 2.83 \text{ kip} \quad M_{\max\_B2} := 2 \cdot R_{\max\_B1} \cdot a_{B2} = 11.31 \text{ kip}\cdot\text{ft}$$

Try W8x18:

$$L_{b\_B2} := 4 \text{ ft} \quad Z_{x\_B1} := 17 \text{ in}^3 \quad L_{p\_B2} := 4.34 \text{ ft} \quad L_{r\_B2} := 13.5 \text{ ft}$$

$$S_{x\_B2} := 15.2 \text{ in}^3 \quad I_{x\_B2} := 61.9 \text{ in}^4 \quad C_b := 1.0 \quad (\text{Assumed}) \quad \Omega := 1.67$$

$$M_{r\_B2} := 531.1 \text{ kip}\cdot\text{in} \quad M_{p\_B2} := 849.7 \text{ kip}\cdot\text{in}$$

$$M_{n\_B2} := C_b \cdot \left( M_{p\_B2} - (M_{p\_B2} - M_{r\_B2}) \cdot \left( \frac{L_{b\_B2} - L_{p\_B2}}{L_{r\_B2} - L_{p\_B2}} \right) \right) = 862 \text{ kip}\cdot\text{in}$$

$$\frac{M_{n\_B2}}{\Omega} = 43 \text{ kip}\cdot\text{ft} > M_{\max\_B2} = 11.3 \text{ kip}\cdot\text{ft}$$

Design of Beam B3

$$L_{B3} := 27 \text{ ft} \quad R_{\max\_B1} = 1413 \text{ lbf} \quad R_{\max\_B2} = 2826 \text{ lbf}$$

$$TA_{B3} := 2 \text{ ft} \quad UL_{B3} := \frac{LC3}{A_{Platform}} \cdot TA_{B3} = 188 \text{ plf}$$

$$R_{\max\_B3} := 4513 \text{ lbf} \quad M_{\max\_B3} := 35.7 \text{ kip}\cdot\text{ft}$$

Try W10x22:

$$L_{b\_B3} := 7 \text{ ft} \quad Z_{x\_B3} := 26 \text{ in}^3 \quad L_{p\_B3} := 4.70 \text{ ft} \quad L_{r\_B3} := 13.8 \text{ ft}$$

$$S_{x\_B3} := 23.2 \text{ in}^3 \quad I_{x\_B3} := 118 \text{ in}^4 \quad C_b := 1.0 \quad (\text{Assumed})$$

$$M_{r\_B3} := 811.6 \text{ kip}\cdot\text{in} \quad M_{p\_B3} := 1300.6 \text{ kip}\cdot\text{in}$$

$$M_{n\_B3} := C_b \cdot \left( M_{p\_B3} - (M_{p\_B3} - M_{r\_B3}) \cdot \left( \frac{L_{b\_B3} - L_{p\_B3}}{L_{r\_B3} - L_{p\_B3}} \right) \right) = 1177 \text{ kip}\cdot\text{in}$$



$$\frac{M_{n\_B3}}{\Omega} = 58.7 \text{ kip}\cdot\text{ft} > M_{\max\_B3} = 35.7 \text{ kip}\cdot\text{ft}$$

Check Deflection for B3

$$\Delta_{\text{Icalc}} := 1.29 \text{ in} \quad @ \text{ 13 ft +/- from support} \quad \Delta_{\text{LLallow}} := \frac{L_{B3}}{360} = 0.9 \text{ in}$$

$$\Delta_{\text{LLcalc}} := 0.69 \text{ in} \quad @ \text{ 13 ft +/- from support} \quad \Delta_{\text{Tallow}} := \frac{L_{B3}}{240} = 1.35 \text{ in}$$

**Conclusion:**

The proposed VZW designed platform is adequate to support all the equipment listed above along with the environmental loads(wind & snow) according to the applicable building code and standards.

Check capacity of existing roof beam 12WF27      TA := 24 ft

(E) Roof Loads,

DL,	Roofing materials	2.0 psf
	Decking	2.0 psf
	Rigid Insulation	1.0 psf
	Steel Joists	2.0 psf
	Misc.	8.0 psf
	<b>Total DL</b>	<b>15.0 psf</b>
SL,	Snow Load	50.0 psf

$$DL := 15 \text{ psf} \quad SL := 50 \text{ psf} \quad R_{\max\_B3\_DL} := 2115 \text{ lbf} \quad R_{\max\_B3\_LL} := 2398 \text{ lbf}$$

$$UDL := DL \cdot TA = 360 \text{ plf} \quad USL := SL \cdot TA = 1200 \text{ plf}$$

**Load Combinations for (E) 12WF27: (Allowable Stress Design)**

ELC1: DL + SL       $R_{\max} := 15301 \text{ lbf}$        $M_{\max} := 64365 \text{ lbf}\cdot\text{ft}$

**Dimensions & Properties of (E) 12WF27**

$$F_y := 36 \text{ ksi}$$

$$A := 7.97 \text{ in}^2 \quad S_x := 34.1 \text{ in}^3 \quad Z_x := 37.5 \text{ in}^3 \quad I_x := 204.1 \text{ in}^4 \quad d := 11.96 \text{ in}$$

$$F_b := 0.66 \cdot F_y = 24 \text{ ksi} \quad S_{\text{req}} := \frac{M_{\max}}{F_b} = 33 \text{ in}^3 < S_x := 34.1 \text{ in}^3 \quad \text{Provided!}$$

**Conclusion:**

The existing roof beam is adequate to support the loads imposed by VZW platform accordingly to the applicable building code and standards.



### Search Result

Elevation Limitation: ASCE 7\* Ground Snow Load  
Query Date: April 03, 2017  
Latitude: 43.646183  
Longitude: -70.266519  
Elevation: 109 Feet

Elevation  $\leq$  500 feet: Ground Snow Load is 50 psf


All loading data is in pounds per square foot.

For a site-specific case study area, a case study is required to establish ground snow loads.

\*Based on Figure 7-1 Ground Snow Loads printed in ASCE 7-95 through ASCE 7-10.

Users should consult with local building officials to determine if there are community-specific snow load requirements that govern.

Red shaded area is the load specific boundaries  
Any darker red area is the overlapping load specific boundary.



### GROUND SNOW LOAD WEBSITE DISCLAIMER

While the information presented on this website is believed to be correct, ATC and its sponsors and contributors assume no responsibility or liability for its accuracy. The material presented in the ground snow load report should not be used or relied upon for any specific application without competent examination and verification of its accuracy, suitability and applicability by engineers or other licensed professionals. ATC does not intend that the use of this information replace the sound judgment of such competent professionals, having experience and knowledge in the field of practice, nor to substitute for the standard of care required of such professionals in interpreting and applying the results of the ground snow load report provided by this website. Users of the information from this website assume all liability arising from such use. Use of the output of this website does not imply approval by the governing building code bodies responsible for building code approval and interpretation for the building site described by latitude/longitude location in the ground snow load report.



Reviewed for Code Compliance  
Inspections Division  
Approved with Conditions  
Date: 10/13/17



[ASCE 7 Windspeed](#)   [ASCE 7 Ground Snow Load](#)   [Related Resources](#)   [Sponsors](#)   [About ATC](#)   [Contact](#)

## Search Results

**Query Date:** Mon Apr 03 2017  
**Latitude:** 43.6462  
**Longitude:** -70.2665

**ASCE 7-10 Windspeeds  
(3-sec peak gust in mph\*):**

**Risk Category I:** 107  
**Risk Category II:** 118  
**Risk Category III-IV:** 127  
**MRI\*\* 10-Year:** 76  
**MRI\*\* 25-Year:** 86  
**MRI\*\* 50-Year:** 91  
**MRI\*\* 100-Year:** 97

**ASCE 7-05 Windspeed:**  
99 (3-sec peak gust in mph)  
**ASCE 7-93 Windspeed:**  
83 (fastest mile in mph)



\*Miles per hour  
\*\*Mean Recurrence Interval

Users should consult with local building officials to determine if there are community-specific wind speed requirements that govern.



[Print your results](#)

### WINDSPEED WEBSITE DISCLAIMER

While the information presented on this website is believed to be correct, ATC and its sponsors and contributors assume no responsibility or liability for its accuracy. The material presented in the windspeed report should not be used or relied upon for any specific application without competent examination and verification of its accuracy, suitability and applicability by engineers or other licensed professionals. ATC does not intend that the use of this information replace the sound judgment of such competent professionals, having experience and knowledge in the field of practice, nor to substitute for the standard of care required of such professionals in interpreting and applying the results of the windspeed report provided by this website. Users of the information from this website assume all liability arising from such use. Use of the output of this website does not imply approval by the governing building code bodies responsible for building code approval and interpretation for the building site described by latitude/longitude location in the windspeed load report.



Total wind load	1207	lbf
Overturing arm length	8	ft
Factor of Safety (FS)	1.5	
Overturing moment	14482	lbf-ft

Overturing resistant weights		
4.89	lbf/ft	L3x3x1/4 angle
18	lbf/ft	W8x18 beam

	length	sections	weight	moment arm length	Resistant moment
	ft	-	lbf	ft	lbf*ft
Part#1	7	3	378	3	1134
Part#2	12	1	216	6	1296
Part#3	7	3	378	9	3402
Part#4	12	1	216	12	2592
Part#7	7	2	68.46	2.25	154
Part#8	7	2	68.46	3.75	257
Part#9	7	2	68.46	8.25	565
Part#10	7	2	68.46	9.75	667
Subtotal			1462	Subtotal	10067

Ballast weights			weight	arm length	Resistant moment
			lbf	ft	lbf*ft
Tray#1			W	3.5	3.5W
Tray#2			W	3.5	3.5W
Tray#3			W	10.5	10.5W
Tray#4			W	10.5	10.5W
Subtotal					28W

Required resistant moment for 28W=	4415	lbf-ft
W	184	lbf
Weight per ballast weight	30	lbf
Ballast weights required	6	per tray
Provided	7	per tray
O.K.		



Reviewed for Code Compliance  
 Inspections Division  
 Approved with Conditions  
 Date: 10/13/17

<b>Sentenia Systems</b>	Project: <b>VZW_Portland 9_ME</b>	Engineer: <b>SA</b>	Project:
		Date: <b>04-Apr-17</b>	Date:
<b>GoBeam</b> Version 2015.1	Subject: <b>Roof Structural Members Analysis</b>	Checker:	Page: <b>1</b>
		Date:	

**LOAD CASE: DL+SL**

ANALYSIS RESULTS				
X, ft	Shear, lb	Moment, lb-ft	Deflections, in	Rotations, rad
0	4266.5	0.00	0.00	-0.04569
1E-06	4266.5	0.00	0.00	-0.04569
1.08	3939.3	4431.11	-0.59	-0.04528
2.16	3612.0	8508.80	-1.17	-0.04408
3.24	3284.8	12233.07	-1.73	-0.04216
4.32	2957.5	15603.93	-2.26	-0.03959
5.4	2630.3	18621.36	-2.75	-0.03643
6.48	2303.1	21285.37	-3.20	-0.03275
7.56	1975.8	23595.97	-3.60	-0.02861
8.64	1648.6	25553.15	-3.94	-0.02408
9.72	1321.3	27156.90	-4.22	-0.01921
10.8	994.1	28407.24	-4.44	-0.01409
11.88	666.9	29304.16	-4.59	-0.00877
12.96	339.6	29847.66	-4.67	-0.00331
14.04	12.4	30037.74	-4.67	0.00221
15	-278.5	29910.00	-4.62	0.00713
15.12	-322.8	29873.92	-4.61	0.00774
16.2	-721.3	29310.12	-4.47	0.01320
17.28	-1119.8	28315.92	-4.27	0.01852
18.36	-1518.3	26891.31	-3.99	0.02361
19.44	-1916.9	25036.30	-3.66	0.02840
20.52	-2315.4	22750.89	-3.26	0.03281
21.6	-2713.9	20035.08	-2.81	0.03676
22.68	-3112.4	16888.87	-2.31	0.04017
23.76	-3510.9	13312.25	-1.77	0.04296
24.84	-3909.5	9305.24	-1.20	0.04505
25.92	-4308.0	4867.82	-0.60	0.04636
27	-4706.5	0.00	0.00	0.04682
27	-4706.5	0.00	0.00	0.04682

Horizontal sway displacements = 0 in

	Max	Min	Area	Area(+)	Area(-)
Shear	4266.5	-4706.5	0.0	30038.0	-30038.0
Moment	30037.74	0.00	541277.76	541277.76	0.00
Deflections	0.00	-4.67	-80.77	0.00	-80.77
Rotations	0.04682	-0.04569	0.00000	0.38939	-0.38939
Reactions	4706.5	4266.5			

Coordinate	Reaction	Displ.
X, ft	R, lb	Δ, in
0	4266.5	0.00
27	4706.5	0.00

ΣR = 8973 lb



Sentenia Systems  GoBeam Version 2015.1	Project: VZW_Portland 9_ME	Engineer: SA	Project
	Subject: 12WF27 Beam Analysis	Date: 04-Apr-17	Date: 10/13/17
		Checker:	Page: 1
		Date:	

**LOAD CASE: DL+SL**

ANALYSIS RESULTS				
X, ft	Shear, lb	Moment, lb-ft	Deflections, in	Rotations, rad
0	14172.4	0.00	0.00	-0.01381
1E-06	14172.4	0.00	0.00	-0.01381
0.64	13174.0	8750.83	-0.11	-0.01370
1.28	12175.6	16862.69	-0.21	-0.01335
1.92	11177.2	24335.57	-0.31	-0.01279
2.56	10178.8	31169.47	-0.41	-0.01204
3.2	9180.4	37364.40	-0.49	-0.01112
3.84	8182.0	42920.35	-0.58	-0.01004
4.48	7183.6	47837.33	-0.65	-0.00881
5.12	6185.2	52115.33	-0.71	-0.00747
5.76	5186.8	55754.35	-0.76	-0.00601
6.4	4188.4	58754.40	-0.80	-0.00447
7.04	3190.0	61115.47	-0.83	-0.00285
7.68	2191.6	62837.57	-0.85	-0.00118
8.32	1193.2	63920.69	-0.85	0.00053
8.96	194.8	64364.83	-0.84	0.00225
9.6	-803.6	64170.00	-0.81	0.00399
10	-1427.6	63723.75	-0.79	0.00506
10	-5940.6	63723.74	-0.79	0.00506
10.24	-6315.0	62253.07	-0.78	0.00570
10.88	-7313.4	57891.97	-0.73	0.00732
11.52	-8311.8	52891.89	-0.67	0.00881
12.16	-9310.2	47252.83	-0.59	0.01016
12.8	-10308.6	40974.80	-0.51	0.01135
13.44	-11307.0	34057.79	-0.42	0.01236
14.08	-12305.4	26501.81	-0.32	0.01318
14.72	-13303.8	18306.85	-0.22	0.01379
15.36	-14302.2	9472.91	-0.11	0.01416
16	-15300.6	0.02	0.00	0.01429
16	-15300.6	0.00	0.00	0.01429

Horizontal sway displacements = 0 in

	Max	Min	Area	Area(+)	Area(-)
Shear	14172.4	-15300.6	0.0	64377.0	-64377.0
Moment	64364.83	0.00	667041.93	667041.93	0.00
Deflections	0.00	-0.85	-8.67	0.00	-8.67
Rotations	0.01429	-0.01381	0.00000	0.07076	-0.07076
Reactions	15300.6	14172.4			

Coordinate	Reaction	Displ.
X, ft	R, lb	Δ, in
0	14172.4	0.00
16	15300.6	0.00

ΣR = 29473 lb



Reviewed for Code Compliance  
Inspections Division  
Approved with Conditions

Date: 10/13/17

# NEXIUS

Accelerating Network and Business Transformation

