

HYDRAULIC DESIGN INFORMATION SHEET

Name - Shalom House Date - 9-2-14
Location - 3rd Floor
Building - System No. - 1 of 1
Contractor - Residential Fire Protection Contract No. - C14021
Calculated By - JAL Drawing No. - 2 of 2
Construction: (X) Combustible () Non-Combustible Ceiling Height 7'-0"
OCCUPANCY - Residential

S Type of Calculation: ()NFPA 13 Residential (X)NFPA 13R ()NFPA 13D
Y Number of Sprinklers Flowing: ()1 ()2 (X)4 ()
S ()Other
T ()Specific Ruling Made by Date
E
M Listed Flow at Start Point - 13 Gpm System Type
Listed Pres. at Start Point - 7 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 16 x 16 () Deluge () PreAction
E Domestic Flow Added - Gpm Sprinkler or Nozzle
S Additional Flow Added - Gpm Make Viking Model VK486
I Elevation at Highest Outlet - 33.25Feet Size 1/2" K-Factor 4.9
G Note:Safety Margin: 14.776 Temperature Rating 155
N

Calculation Gpm Required 52.516 Psi Required 55.156 At Test
Summary C-Factor Used: Overhead 150 Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - 10-31-13 Rated Cap. Cap.
T Time of Test - @ Psi Elev.
E Static (Psi) - 70 Elev.
R Residual (Psi) - 62 Other Well
Flow (Gpm) - 691 Proof Flow Gpm
S Elevation - -20

P Location:
P
L Source of Information:
Y

Water Supply Curve (C)

Residential Fire Protection
Shalom House 3rd floor unit


Page 2
Date 9-2-14

City Water Supply:

C1 - Static Pressure : 70
C2 - Residual Pressure: 62
C2 - Residual Flow : 691

Demand:

D1 - Elevation : 8.662
D2 - System Flow : 52.5157
D2 - System Pressure : 55.156
Hose (Adj City) : _____
Hose (Demand) : _____
D3 - System Demand : 52.5157
Safety Margin : 14.776



Fittings Used Summary

Residential Fire Protection
Shalom House 3rd floor unit

Page 3
Date 9-2-14

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	Generic Gate Valve	0	0	0	0	0	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
N	CPVC 90'EI Harvel-Spears	7	7	7	8	9	11	12	13	0	0	0	0	0	0	0	0	0	0	0	0
O	CPVC Tee - Branch	3	3	5	6	8	10	12	15	0	0	0	0	0	0	0	0	0	0	0	0
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Z	Generic Flow Switch	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
Zaa	Ames 2000B	Fitting generates a Fixed Loss Based on Flow																			

Pressure / Flow Summary - STANDARD

Residential Fire Protection
Shalom House 3rd floor unit

Page 4
Date 9-2-14

Node No.	Elevation	K-Fact	Pt Actual	Pn	Flow Actual	Density	Area	Press Req.
DP1	33.25	4.9	7.04	na	13.0	0.1	130	7.0
DP2	33.25	4.9	7.04	na	13.0	0.1	130	7.0
DP3	33.25	4.9	7.04	na	13.0	0.1	130	7.0
1	0.0	K = K @ DRP1	22.77	na	13.18			
1A	0.0		23.66	na				
2	0.0	K = K @ DRP1	22.15	na	13.0			
3	0.0	K = K @ DRP3	22.95	na	13.13			
4	0.0	K = K @ DRP1	22.86	na	13.21			
5	0.0		23.95	na				
6	0.0		24.16	na				
7	0.0		24.05	na				
8	0.0		24.04	na				
9	0.0		24.96	na				
10	0.0		25.48	na				
11	0.0		25.61	na				
20	0.0		25.82	na				
22	0.0		25.95	na				
21	0.0		26.36	na				
25	0.0		31.41	na				
26	0.0		36.19	na				
TR	0.0		37.87	na				
BR	0.0		43.84	na				
UG1	0.0		46.47	na				
TEST	-20.0		55.16	na				

The maximum velocity is 11.27 and it occurs in the pipe between nodes 21 and 25

Final Calculations - Hazen-Williams

Residential Fire Protection
Shalom House 3rd floor unit

Page 5
Date 9-2-14

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
DP1 to DRP1	13.00 13.0	0.874 150 0.0943	1N	7.0 0.0 0.0	0.500 7.000 7.500	7.039 14.401 0.707			K Factor = 4.90 Vel = 6.95	
	0.0 13.00						22.147		K Factor = 2.76	
DP2 to DRP2	13.00 13.0	0.874 150 0.0943	1O	3.0 0.0 0.0	0.500 3.000 3.500	7.039 14.401 0.330			K Factor = 4.90 Vel = 6.95	
	0.0 13.00						21.770		K Factor = 2.79	
DP3 to DRP3	13.00 13.0	0.874 150 0.0944	1N 1O	7.0 3.0 0.0	1.350 10.000 11.350	7.039 14.401 1.071			K Factor = 4.90 Vel = 6.95	
	0.0 13.00						22.511		K Factor = 2.74	
1 to 1A	13.18 13.18	0.874 150 0.0969		0.0 0.0 0.0	9.210 0.0 9.210	22.772 0.0 0.892			K Factor @ node DRP1 Vel = 7.05	
1A to 5	0.0 13.18	1.101 150 0.0315	1O	5.0 0.0 0.0	4.080 5.000 9.080	23.664 0.0 0.286			Vel = 4.44	
	0.0 13.18						23.950		K Factor = 2.69	
2 to 3	13.00 13.0	0.874 150 0.0944		0.0 0.0 0.0	8.460 0.0 8.460	22.147 0.0 0.799			K Factor @ node DRP1 Vel = 6.95	
3 to 8	13.13 26.13	1.101 150 0.1115	1O	5.0 0.0 0.0	4.830 5.000 9.830	22.946 0.0 1.096			K Factor @ node DRP3 Vel = 8.81	
	0.0 26.13						24.042		K Factor = 5.33	
4 to 7	13.21 13.21	0.874 150 0.0973	1O	3.0 0.0 0.0	9.170 3.000 12.170	22.863 0.0 1.184			K Factor @ node DRP1 Vel = 7.06	
	0.0 13.21						24.047		K Factor = 2.69	
5 to 6	13.18 13.18	1.101 150 0.0314		0.0 0.0 0.0	6.650 0.0 6.650	23.950 0.0 0.209			Vel = 4.44	
6 to 7	-31.24 -18.06	1.101 150 -0.0560		0.0 0.0 0.0	2.000 0.0 2.000	24.159 0.0 -0.112			Vel = 6.09	
7 to 8	13.20 -4.86	1.101 150 -0.0059		0.0 0.0 0.0	0.850 0.0 0.850	24.047 0.0 -0.005			Vel = 1.64	
8 to 9	26.13 21.27	1.101 150 0.0762		0.0 0.0 0.0	12.040 0.0 12.040	24.042 0.0 0.918			Vel = 7.17	

Final Calculations - Standard

Residential Fire Protection
Shalom House 3rd floor unit

Page 6
Date 9-2-14

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftg's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	0.0 21.27									
						24.960			K Factor =	4.26
6 to 10	31.25	1.101 150		0.0	8.500	24.159				
	31.25	0.1554		0.0	8.500	1.321			Vel =	10.53
	0.0 31.25									
						25.480			K Factor =	6.19
9 to 11	21.27	1.101 150		0.0	8.500	24.960				
	21.27	0.0764		0.0	8.500	0.649			Vel =	7.17
	0.0 21.27									
						25.609			K Factor =	4.20
10 to 11	4.97	1.101 150	2O	10.0	14.900	25.480				
	4.97	0.0052		0.0	10.000	0.0			Vel =	1.67
	0.0 4.97									
						25.609			K Factor =	0.98
10 to 20	26.27	1.394 150		0.0	9.500	25.480				
	26.27	0.0357		0.0	9.500	0.339			Vel =	5.52
	0.0 26.27									
						25.819			K Factor =	5.17
11 to 22	26.24	1.394 150		0.0	9.500	25.609				
	26.24	0.0356		0.0	9.500	0.338			Vel =	5.52
	0.0 26.24									
						25.947			K Factor =	5.15
20 to 21	26.27	1.394 150	1O	6.0	9.250	25.819				
	26.27	0.0357		0.0	6.000	0.0			Vel =	5.52
	0.0 26.27									
						26.364			K Factor =	5.12
22 to 21	26.24	1.394 150	1O	6.0	5.690	25.947				
	26.24	0.0357		0.0	6.000	0.0			Vel =	5.52
	0.0 26.28									
						26.364				
21 to 25	52.52	1.38 120	2T 1E	12.0 3.0	9.700 15.000	26.364 0.0				
	52.52	0.2042		0.0	24.700	5.043			Vel =	11.27
	0.0 52.52									
						31.407				
25 to 26	52.52	1.38 120	1T	6.0	17.440	31.407				
	52.52	0.2041		0.0	6.000	0.0			Vel =	11.27
	0.0 52.52									
						36.192				
26 to TR	52.52	1.61 120	1E 1T	4.0 8.0	5.460 12.000	36.192 0.0				
	52.52	0.0964		0.0	17.460	1.683			Vel =	8.28
	0.0 52.52									
						37.875				
TR to BR	52.52	2.067 120	1Zaa 1Z	0.0 5.0	4.000 5.000	37.875 5.712			* Fixed loss =	5.712
	52.52	0.0286		0.0	9.000	0.257			Vel =	5.02

Final Calculations - Standard

Residential Fire Protection
Shalom House 3rd floor unit

Page 7
Date 9-2-14

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
BR	0.0	1.72	1G	0.617	50.000	43.844			
to		150	1T	6.174	6.792	0.0			
UG1	52.52	0.0462		0.0	56.792	2.625		Vel = 7.25	
UG1	0.0	8.27		0.0	1000.000	46.469			
to		140		0.0	0.0	8.662			
TEST	52.52	0.0		0.0	1000.000	0.025		Vel = 0.31	
	0.0								
	52.52					55.156		K Factor = 7.07	