

SHEEL NOTES:

ADDRESSABLE MONITOR MODULE(S) PROVIDED TO MONITOR ALL WATER FLOW, PRESSURE SWITCHES, TAMPER SWITCHES AND POST INDICATING VALVES ASSOCIATED WITH THE FIRE SPRINKLER SYSTEM. INSTALLING CONTRACTOR SHALL FIELD VERIFY EXACT MOUNTING, CIRCUITING AND PROGRAMMING REQUIREMENTS. FIELD VERIFY EXACT QUANTITY AND LOCATION(S).

shop drawings created by:
5794 W. 4600 So.
Hooper, UT 84315
Office: 801.985.0410

www.unicod.net

DRAWN
UNICAD JOB #14
CHECKED
WAYNE B. HAWS
NICET IV 90496
DATE
10/17/2014
REVISION
0
SCALE
1/4"=1'-0"

SHALOM HOUSE
214 DANFORTH STREET
PORTLAND, MAINE 04102
BASEMENT FIRE ALARM PLAN



Security Systems

10 Princes Point Road, Yarmouth, Maine 04096
Office: 207.846.3350 • Fax: 207.846.6080

REVISION	DESCRIPTION	DATE
0	ISSUED FOR REVIEW & APPROVAL	10/17/201
		ĺ